

G-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/BNQT/2023/SZ/36

Dated: 14/09/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Kangna Banquets running at ground floor only, in a building comprised of ground plus three upper floors (ground floor banquet hall, first & second floor rooms and third floor storage) located at Plot No. 1,2 & 5, Z- Block Extn., Main, Najafgarh Road, Uttam Nagar, New Delhi-110059, owned/occupied by Kangna Banquets. The Banquet hall building was inspected by the officers concerned of this department on 01/09/2023 in the presence of Mr. Sourav Gandhi and found that the building/premises have complied with the fire prevention and fire safety requirements in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D "Assembly Building" with effect from ..14/09/2023 for a period of three years, subject to conditions printed below.

Issued on14/09/2023..... at New Delhi by

(Atul Garg)

Director
Delhi Fire Service

To,

The Manager,
M/s Kangna Banquets, Plot No. 1,2 & 5, Z- Block Extn., Main, Najafgarh Road, Uttam Nagar,
New Delhi-110059 .

Copy to:-

Dy. Health Officer SDMC Public Health Department,
West Zone, Rajouri Garden, New Delhi 110027.

Following fire safety directives must be adhered to:-

- The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
- This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- * The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s Kangna Banquets, Plot No. 1,2 & 5, Z- Block Extn., Main Najafgarh Road, Uttam Nagar, New Delhi-110059
2. Building comprised of : Ground plus three upper floors (ground floor having metallic roof used as banquet hall, first & second floor used as rooms and third floor used a storage)
3. Type of Occupancy : Assembly Building
4. Type of Case : New
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2023/36 dated 03/02/2023
7. Date of inspection : 01/09/2023
8. Name of Inspecting Officer : A.D.O. R.K.Yadav & D.O Vedpal Chhikara
9. Name and designation of officers : Mr. Sourav Gandhi
10. Year of Construction : 2017
11. Applicant's letter No. : ID No. 2023082515156 dated 25/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to building	06 m	25 m Provided	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02 no.'s	Provided	MR
	• Upper Floors	N/A	N/A	N/A
	• Basements			
	b. Width of staircases	1.5 m each	1.62 & 1.50 m	MR
	• Upper Floor	N/A	N/A	N/A
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	N/A	N/A	N/A
	• Pressurization			
	d. No. of continuous staircases to terrace	2 no.'s	Provided	MR
		N/A	N/A	N/A
	e. Width of Corridor	2.0 m	3 x 2.0 m	MR
	f. Door Size			
3.	Compartmentation	Required	Provided	MR
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10 no.'s	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor (Gr.Floor)	03 no.'s	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

b lw

7.	Automatic fire detection and alarming system			
	• Type of detectors Smoke/Heat	Required	Provided	MR
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	At exits	MR
8.	MOEFA With talk back system			
		Required	Provided	MR
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	Three	Provided	MR
	• Hose Box	Three	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Terrace Level			
	> Discharge of main Pump	2280 LPM	Provided	MR
	> Head of Main pump	60 mtrs.	Provided	MR
	> Number of main pumps	One	Provided	MR
	> Jockey Pump out put	180 LPM	Provided	MR
	> Jockey pump head	60 mtrs.	Provided	MR
	> Standby Pump out put	2280 LPM	Provided	MR
	> Standby Pump Head	60 mtrs.	Provided	MR
	> Auto Starting/Manual Stopping	Required	Provided	MR
	> Pump House Access	Required	Provided	MR
	• Ground level			
	> Discharge of pump	N/A	N/A	N/A
	> Head of the pump	N/A	N/A	N/A
	> Power Supply	N/A	N/A	N/A
	> Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	> Draw-off connection	N/A	N/A	N/A
	> Fire service inlet	N/A	N/A	N/A
	> Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	1,00,000 & 5,000 ltrs	Provided	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply			
		Required	Provided	MR


15


Refuge Area.			
	➤ Total Area	N/A	N/A
	➤ Location	N/A	N/A
19.	Fire Control Room		
	• Detector System Panel	N/A	N/A
	• Flow Switch Panel	N/A	N/A
	• PA System Panel	N/A	N/A
	• Battery backup	N/A	N/A
	• Building Floor Plans	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter No. F6/Delhi Fire Service/MS/Banquet/2023/SZ/141 dated 06/06/2023 has been complied.



Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

Building comprised of ground plus three upper floors (ground floor having metallic roof used as banquet hall, first & second floor used as rooms and third floor used as storage)


 Signature of the Inspecting Officer
 Name :-R.K.Yadav
 Designation:-ADO (JKP)


 Signature of the Inspecting Officer
 Name :-Vedpal Chhikara
 Designation:- DO (SW)

CFO (South Zone) 
 7/9/2023

 Director 
 11/9/2023

