



2/14

75
आजादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/College/WZ/2023/130

Dated: 15/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Auditorium Building, Satyawati College located at Ashok Vihar Ph- III, New Delhi-110052, in a building comprised of Ground plus one upper floor. Owned/occupied by Auditorium Building, Satyawati College was issued FSC vide letter no.- F6/DFS/MS/2014/150 dated 31/01/2014. The premises was re-inspected by the officer concerned of this department on 01/09/2023 in the presence of Sh. Kamal Raj (Manager) and observed that all the fire prevention and fire safety arrangements provided in the building/premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Services Rule 2010 and the building/premises is fit for occupancy class "Assembly" (Group - D) with effect from 15/09/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 15/09/2023 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Principal, Satyawati College located at Ashok Vihar Ph- III, New Delhi-110052.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building	Satyawati College located at Ashok Vihar Ph- III, New Delhi-110052.
2. Type of Occupancy	Assembly
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/2014/150 dated 31/01/2014
5. Fire Safety directives letter No	F6/DFS/MS/BP/2006/1858 dated 01/08/2006
6. Date of inspection	01/09/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Smt. Kamal Raj (Manager)
9. Year of Construction	2005-2006 (As per prev. insp. report dtd.- 29/11/2022)
10. Applicant's letter No.	Email dated - 12/08/2023

* The Auditorium Building, Satyawati College is comprised of ground plus one upper floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As Per DOE No. 3298-3398 dated 01/03/20211	Provided at site	Remarks MR/MR
1	Access to building			
	• Road width	12 m	Provided	MR
	• Gate width	05 m	Provided	MR
	• Width of internal road	06 m	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	02	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1.5 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	18 mos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

SARABJEET SINGH

KAMAL RAJ

6	First-Aid Hose Reels.			MR
	• Total numbers on each floor	04	04 at G.F 02 at F.F	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			MR
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	GF & FF	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			NA
	• Basement	NA	NA	---
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			MR
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	04 nos	Provided	MR
	• Hose Box	04 nos	Provided	MR
12	Yard Hydrants.			NA
	• Total number of hydrants	NA	NA	MR
	• Hose Box	04	Provided	MR
13	Pumping Arrangements.			MR
	• Ground Level			MR
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main pump	70 MH	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	220 LPM	Provided	MR
	➤ Jockey pump head	70 MH	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	70 MH	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			MR
	➤ Discharge of pump	220 LPM	Provided	MR
	➤ Head of the pump	50 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			MR
	• Underground tank capacity	50000 ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA
	• Pressurization of Lift lobby	NA	NA
	• Communication In lift Car	NA	NA
	• Fireman's Grounding Switch	NA	NA
	• Lift Signage	NA	NA
17	Standby power supply	Required	Provided
18	Refuge Area.		
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19	Fire Control Room		
	• Detector System Panel	Required	Provided
	• Flow Switch Panel	Required	Provided
	• PA System Panel	Required	Provided
	• Batter backup	Required	Provided
	• Building Floor Plans	Required	Provided
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F.6/DFS/MS/WZ/2022/75 dated 15/12/2022 have been complied.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2014/150 dated 31/01/2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Dy CEO (WZ)~~

~~Sarabjeet Singh~~
11/9/2023

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

~~dy~~ 11/9/2023

~~cto~~ 12/9/2023

~~Dir~~ 12/9/23

put up F.T.

~~dy~~
13/9/23

~~ADO (MN)~~

~~Dy CEO (WZ)~~

~~ADO (MN)~~
Dated: 11/9/2023