

C-77

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6/DFS/MS/2023/School/WZ/645

Dated: 18/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Delhi Public School, P. No. 01, Sec-24, Phase-III, Rohini, Delhi-85 comprised of Ground + Three upper floors owned / occupied by Delhi Public School was issued fire safety certificated vide this office letter No F.6/DFS/MS/2020/WZ/School/264 dated: 04.08.2020 and have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of fire service on 14.08.2023 in the presence of Mr. Rafiq and that the building/ premise is fit for occupancy Group B (Educational) with effect from ..18/09/2023. for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010 subject to compliance of the condition mentioned below:

Issued on ..18/09/2023..... at New Delhi

  
(Atul Garg)  
DIRECTOR  
Ph: 011-23414000  
Atul Garg

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Delhi Public School, P. No. 01, Sec-24, Phase-III, Rohini, Delhi-85.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rule](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule)  
s/ [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)



N/25

**INSPECTION REPORT**

1. Name & address of the building : Delhi Public School, P. No. 01, Sec-24, Phase-III, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + Three upper floors)
4. Details of previous NOC : F.6/DFS/MS/2020/WZ/School/264 Dated: 04.08.2020
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 14.08.2023
7. Name of the Inspecting Officers : A.K. Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Mr. Rafiq
9. Year of Construction : 2000
10. Applicant's letter No. : Online e-mail dated 04.07.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	6m	MR
	• Gate width	4.50m	4.50m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02	02 + 02 ramp	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	02 m	Provided	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1 m	1 m	MR
f. Door Size				
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	3300 @ per m2 32	47nos	MR
	• Types	ABC	ABC	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02 in each floor	Provided	MR
	• Length of hose reel hose	30 m	30m	MR

*[Handwritten signature]*

*[Handwritten signature]*



	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	5mm	
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	MR
9	<b>Public Address System.</b>	Required	Provided	
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	4"	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	02	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	02	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NR	Provided	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NR	Provided	NA
13	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	180 lpm	180 lpm	MR
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	40m	40m	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>			
	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>	450 lpm X 2	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	40m	40m	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	NA	NA	NA
<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	NA	NA	NA	
<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	NA	NA	NA	
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>	50,000 ltr	60,000 ltr	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	10,000ltrs	40,000 ltr.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			

24

X

M  
NA  
NA  
NA

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2020/WZ/School/264 dated: 04.08.2020 renewal under rules 37 of the Delhi Fire Service rules 2010 is recommended. .

*[Signature]*  
16/8/23

Signature of Inspecting Officer  
Name: A. K. Sharma  
Designation: Divisional Officer

Dy. CFO (MKC)  
*[Signature]*

*[Signature]*  
16/8/2023

M.K. CHATTOPADHYAY

DCFO/...37...  
Dated...16/08/23...  
*[Signature]*

*[Signature]*  
18/8/2023  
Director *[Signature]* 18/9/23 FTPS

2 FT letter is placed for your signatures please  
*[Signature]*