



FIRE SAFETY CERTIFICATE

Certified that M/s. Hotel Marble Arch located at 8/6, W.E.A, Pusa Lane, Karol Bagh, New Delhi- 110005 was granted Fire Safety Certificate vide this department letter No. F.6/DFS/MS/GH/SZ/2021/298 dated 11.08.2021, for building comprised of basement, ground plus two upper floors, using basement (storage), ground floor (reception, office and 05 rooms for personal use), first and second floor each having 11 guest rooms respectively (total 22 guest rooms only). The premises was re-inspected by the officers concerned of this department on dated 01.09.2023 in presence of Sh. Dasrath Gosawami, Manger of the guest house, and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) for basement (storage), ground floor (reception, office and 05 guest rooms), first and second floor each having 11 guest rooms respectively (total 27 guest rooms only) with effect from 18/09/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 18/09/2023 at New Delhi by.


Atul Garg
Director
Delhi Fire Service

Application Id No. 2023082515168 dated 28.08.2023

Following Fire Safety Directives must be adhered to: -

1. No occupancy used above second floor and basement used for storage purpose only shall be strictly adhered by Owner/Occupier.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Hotel Marble Arch, 8/6, W.E.A, Pusa Lane, Karol Bagh, New Delhi- 05
2. Type of Occupancy : Lodging House
3. Building Composition : Said guest house building comprised of basement, ground plus two upper floors, using basement as storage, ground floor as reception, offices & 05 guest rooms, 1st & 2nd floor each having 11 guest room respectively (total 27 guest rooms only)
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/GH/SZ/2021/298 dated 11.08.2021.
6. Fire Safety directives letter No : Nil
7. Date of inspection : 01.09.2023
8. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW)
9. Name and designation of officers from the building side : Sh. Dashrath Goswami, manger
9. Year of Construction : 2009-10
10. Applicant's letter No. : Online Application Id 2023082515168 dated 28.08.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety arrangements as per FSC dt. 11.08.2021	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	N/A	Directly accessible	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases	-	-	-
	• Upper Floors	Old case	1.48, 0.92 mts (iron made)	MR being old case
	• Basements	Old case	1.42, 1.60 mts.	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	02	MR
	g. Width of Corridor	Old case	1.45 to 2.75 mts	MR being old case
	h. Door Size	Old case	0.80 mts	MR being old case
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types IS marking 	12 CO ₂ , ABC, WCO; ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided	MR
			Provided	MR
			Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Carbon Monoxide	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		Required	D.G. set 200 KVA	MR
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	---	---	---
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		-----	-----	-----
		450 LPM	900 LPM	MR
		40 mts	40 mts	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 lts	10,000 lts	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			

W

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked at random and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter F.6/DFS/MS/GH/SZ/2021/298 dated 11.08.2021, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval & signature please.

[Handwritten Signature]
4/9/23

Signature of the Inspecting Officer
Name- Vedpal Chhikara
Divisional Officer (SW)

CFO(S2)

[Handwritten Signature]
6/9/2022

Director [Handwritten Signature]

This is the case of
addition of room
ask for
drgs

D/SW

P.T.O.