

C 34

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/2023/School/WZ/644

Dated: 18/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Vidhya Sagar Public School, O-1/50, Budh Vihar, Phase-1, Delhi-86, comprised of Ground + 01 upper floor owned/occupied by Vidhya Sagar Public School was granted FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2020/492 dated 09.11.2020. The premises was re-inspected by the officer concerned of this department on 22.08.2023 in the presence of Sh. Krishan Pal (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ...18/09/2023.... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ..18/09/2023..... at New Delhi

  
(Atul Garg)  
DIRECTOR

Ph; 011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Vidhya Sagar Public School, O-1/50, Budh Vihar, Phase-1, Delhi-86.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building : Vidhya Sagar, public School, O-1/50, Budh Vihar, Phase-1, Delhi-86
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground + 01 upper floor)
4. Details of Previous NOC : F.6/DFS/MS/School/WZ/2020/492 dated 09.11.2020.
5. Fire Safety directives letter No : Director of Education Cir. dated 01.03.2011.
6. Date of inspection : 22.08.2023
7. Name of Inspecting Officer : Sh. Ajay Kumar Sharma (ADO Rohini)
8. Name and designation of officers  
From the building side : Sh. Krishan Pal (Principal)
9. Year of Construction : 2018
10. Applicant's letter No. : OD No.4451 dated 03.08.2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Cir. Dir. of Education 2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	2 x 1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	<b>Fire Extinguishers</b>			
	• Total numbers	08nos.	08nos.	MR
	• Types	ABC/CO2	ABC-08nos.	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

*Ajay*

*[Signature]*

N/12

	<ul style="list-style-type: none"> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA	NA		NA
8.	<b>MOEFA</b>	NA	NA		NA
9.	<b>Public Address System</b>	NA	NA		NA
10.	<b>Automatic Sprinkler System</b>				
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Ground &amp; Upper Floors</li> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
11.	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
12.	<b>Yard Hydrants</b>				
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	NA		NA
		NA	NA		NA
13.	<b>Pumping Arrangements</b>				
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> <li>➤ Pump House Access</li> </ul> </li> </ul>	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
14.	<b>Captive Water Storage for fire fighting</b>				
	<ul style="list-style-type: none"> <li>• Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
15.	<b>Exit Signage.</b>	NA	NA		NA
16.	<b>Provision of Lifts.</b>				
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
		NA	NA		NA
17.	<b>Standby power supply</b>	NA	NA		NA
18.	<b>Refuge Area.</b>				
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA		NA
		NA	NA		NA
19.	<b>Fire Control Room</b>				
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	NA	NA		NA

*Handwritten signatures and marks at the bottom of the page.*

N/13

N/A

Flow Switch Panel	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2020/492 dated 09.11.2020 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer  
Name Ajay Kumar Sharma  
Designation ADO(Rohini)

Dy. CFO (WZ)

166  
~~12/09/22~~

12/8

cfo  
  
13/9/2022

Director  
  
14/9/22

~~Any for~~

FT letter is put up for kind  
perusal and signature please.

Director  
  
10/9/22

18/9/22