

c/149

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2023/SZ/662

Dated: 21/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Apeejay School located at Sheikh Sarai Phase-1, Panchsheel Park, New Delhi 110017 comprised of **Block-A** (Basement, Ground + 04 Upper Floors) **Block -E** (Ground + 04 Upper floors and **Old Block-Auditorium** (Basement, Ground + 01 Upper Floor) owned/occupied by Apeejay School was issued FSC by this department vide letter No. F6/DFS/MS/School/2020/SZ/291 dated 18-08-2020. The premises was re-inspected by officer concerned of this department on 14/09/2023 in the presence of Mr. Balwant Sharma (Admin) and found that the premise have deemed complied with the fire prevention and fire safety requirements in accordance with fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that building is fit for occupancy class "**Educational, Group-B**" with effect from 21/09/2023 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 21/09/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Apeejay School located at Sheikh Sarai Phase-1, Panchsheel Park, New Delhi 110017
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/49

INSPECTION REPORT

1	Name & Address of the Building	APEEJAY SCHOOL, SHEIKH SARAI, PHASE-I, NEW DELHI-110017		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	New Blk (A)=B+G+4, New Blk (E)=G+4 and Auditorium (Old)= B+G+1		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2020/SZ/291 dated 18-08-2020		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2003/169 Dtd 20/01/2003 (Audi) F.6/DFS/MS/BP/2016/05 Dtd 14/01/2016 (Blk-B&E)		
7	Date of Inspection	14/09/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Balwant (Admin)		
10	Year of construction	Audi=2005 & School= 2018		
11	Applicant letter No.	Email dated 05-09-2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC/UBBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 mtr	Provided	MR
		6 mtr	Provided	MR
		6 mtr	Provided	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	> Upper floors.	New Blk (A)=2 Nos New Blk (E)=3 Nos Auditorium= 2 Nos	Provided Provided Provided	MR MR MR
	> Basement floor.	New Blk (A)=2 Nos Auditorium= 4 Nos	Provided Provided	MR MR
	b) Width of Staircase			
	> Upper floors	1.5m	New Blk (A)=1.50m, 1.50m & 2x 1.50m (Iron) & ramp of 1.40m GF to FF New Blk (E)=1.83m each	MR
	> Basement floor	1.5m	1.50m, 1.50m & ramp 3.10m, 1.80m	MR
	c) Protection of exits			
	> Fire check door	Required	Provided	MR
	> Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	2 each block	Provided	MR
	e) Width of corridor	1.5 mtr	2.90m	MR
	f) Door size	C/Room=1.2m Auditorium=1.5m	Provided 1.35m (old case)	MR MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Provided	MR
5	Fire Extinguishers.			
	• Total numbers		100 Nos	MR
	• Types	ISI mark	ABC=60 & CO2=40	MR
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	Blk (A)=2, Blk (E)=3 & Audi=4 Nos	Blk (A)=2, Blk (E)=3 & Audi=4 Nos	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR
7	Automatic fire detection & alarming system.			

~

Y

M/50

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Audi & E Blk	Provided	MR
		Required	Ground floor	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		All areas	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System			
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required in Audi (Wooden stage)	Provided	MR
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100mm	Provided	MR
		Blk (A)=2, Blk (E)=3 & Audi=4 Nos	Blk (A)=2, Blk (E)=3 & Audi=4 Nos	MR
		Blk (A)=2, Blk (F)=3 & Audi=4 Nos	Blk (A)=2, Blk (F)=3 & Audi=4 Nos	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	Provided	-NA-
		-NA-	Provided	-NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	2850 LPM	2850 LPM (two)	MR
		80m	80m	MR
		2 Nos	2 Nos	MR
		180 LPM	180 LPM	MR
		80m	80m	MR
		2850 LPM	2850 LPM	MR
		80m	80m	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	Blk (A)=900 LPM, Blk (E)=900 LPM & Audi=900 LPM	Blk (A)=900 LPM, Blk (E)=900 LPM & Audi=900 LPM	MR
		40m (each)/35m	45m, 45m & 35m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,00,000 Lts	-NA-	-NA-
		Required	-NA-	-NA-
		Required	-NA-	-NA-
		Required	-NA-	-NA-
		Blk (A)=10,000 Ltr, Blk (E)=25,000 Ltr Audi=10,000 Ltr	Blk (A)=10,000 Ltr, Blk (E)=25,000 Ltr Audi=10,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	Ground floor	Provided	MR

Y

N/51



	<ul style="list-style-type: none"> • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		Ground floor	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of Special Risk, if any.	Gas suppression system in LT/HT Panel found provided		MR

Apeejay School, Sheikh Sarai Phase-I, New Delhi-110017

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2020/SZ/291 dated 18-08-2020, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

merh

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

M
13/9/23

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

King
19/9/2023

Director

[Handwritten signature]
19/9/23
[Handwritten signature]

As approved, F.T. letter is put up for your signature P1

1/14
2/19

Director

[Handwritten signature]
19/9/23
[Handwritten signature]