

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2023/ School/ 649

Dated: 20/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Ramjas Sr. Secondary School No. 4** located at **Chitra Gupta Road, Pahar Ganj, New Delhi – 110055** is comprised of **Ground + 01 Upper floor except auditorium**, was earlier granted FSC by this department vide letter No. **F6/DFS/MS/2020/school/281** dated **14/08/2020**. Now, the premises was re-inspected by the officer concerned of this department on **13-09-2023** in the presence of **Pt. Raghuvinder Gautam** (Head of School) and found that school building has deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398** dated **01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B “Educational Building” Sub-Div. B-I except auditorium** with effect from.....**20/09**...2023 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on .....**20/09/2023** at New Delhi by.

  
 (Atul Garg)  
 DIRECTOR  
 Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, Ramjas Sr. Secondary School No. 4, Chitra Gupta Road, Pahar Ganj, New Delhi - 110055.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of Unauthorized construction, if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.
7. Any flammable material for interior decoration shall strictly prohibited.



**INSPECTION REPORT**

1. Name & address of the building:- Ramjas Sr. Secondary School No. 4 at Chitra Gupta Road, Pahar Ganj, New Delhi. Educational Group B-I, Gr.+01 Upper Floor
2. Type of occupancy:- Renewal
3. Type of case:- F6/DFS/MS/2020/school/281 dated 14/08/2020
4. Details of previous NOC:- N/A
5. Fire safety directives No.- 13/09/2023
6. Date of inspection:- Sh. Ravinder Singh(ADO/CC)
7. Name of the inspecting officer:- Pt. Raghuvinder Gautam (Head of School)
8. Name & designation of officer From the building side:- 1933
9. Year of construction:- letter no. 998 dated 14.08.2023.
10. Applicant's letter No:- Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	18 mtr.	MR
	2) Gate width	-----	3.60, 3.0 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	03	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 & 0.75mtr	1.57, 1.36 & 1.36 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	03	03	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	09 Nos.	09 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			



N/16

	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

*(Handwritten signatures and marks)*


N/17

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: fire bucket			MR

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/2020/school/281 dated 14/08/2020, renewal under Rule 35 of the Delhi Fire Service rules 2010, Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

  
 Name :- Ravinder Singh  
 Designation :- ADO (CC)

~~Dy. Insp.~~  
 14/9/23  
 Dy. Insp. (In-charge)  
 C.F.O.  
 15/9/2023  
 Director  
 15/9/2023

ADU/CS