



C-54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/WZ/665

Dated: 21/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Rani Public School located at 16/10, Block- A1, Sant Nagar, Burari, Delhi-110084 comprised of Ground & 02 upper floors only owned/ occupied by Rani Public School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/2020/WZ/School/431 Dated 19.10.2020. The premise was inspected by the officer concerned of this department on 12.09.2023 in the presence of Smt. Neetu Saini (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Educational Group B" with effect from ...21/09/2023 for a period of **Valid up to 31.03.2026** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under

Issued on ...21/09/2023 at New Delhi by

(Atul Garg)
Director
Ph:-011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Rani Public School located at 16/10, Block- A1, Sant Nagar, Burari, Delhi- 110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Rani Public School at Sant Nagar, Burari Road, Delhi-110084.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : Ground & 02 upper floors only
5. Details of previous NOC : F6/DFS/MS/2020/WZ/School/431 Dated: 19.10.2020
6. Fire Safety directives letter No : Nil
7. Date of inspection : 12.09.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Smt. Neetu Saini (Principal)
10. Year of Construction : 2007/2013/2019
11. Applicant's letter No. : Online Email ID Dated-06.09.2023

	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.50m	4.50m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m each	02m & 80cm (Ground to 1 st floor) 1.50m & 1.23m (Ground to Terrace) & 1.50m (1 st floor to 2 nd floor)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m & 1.20m	01m & 1.20m(2 nd floor)	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	08nos	12nos	MR

	<ul style="list-style-type: none"> Types ISI marking 	ABC/CO2	ABC-10/Co2-2	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	01	01	MR
	Length of hose reel hose	30m	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			

MR	• Underground tank capacity	NA	NA	NA
MR	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	10,000 LTR	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, the FSC issued vide letter of even no. F6/DFS/MS/2020/WZ/School/431 dated 19.10.2020 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation :- ADO/RN

M.K. Chattopadhyay
Dy. Chief Fire Officer (WZ)

WFO-194
Date: 13/10/2023

13/9
14/10/2023
Director

ADO/RN

Conf. - - P.T.O