



C 19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

75  
आजादी का  
अमृत महोत्सव

No F 6 / DFS / MS / 2023 / School / WZ / 668

Dated: 21/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Sant Gyaneshwar Model School** located at **Lakhmi Enclave, Extended Lal Dora, Alipur, Delhi-110036** comprised of 02 Blocks (Ground plus two upper floor & Ground plus three upper floors) owned/occupied by **Sant Gyaneshwar Model School**. The premise was inspected by the officer concerned of this department on 15.09.2023 in the presence of Sh. Prem Singh Mann (Chairman) and observed that the fire safety measures are in accordance with rule 33 of the Delhi Fire Service Rules, 2010 have deemed complied and that the building is fit for occupancy class B "Educational building" with effect from 21/09/2023 for a period of **three years**, in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...21/09/2023... at New Delhi, by

  
(Atul Garg)  
Director  
Ph. 011-23414000  


Copy to :-

1. The Director, Education, Old Secretariat , Delhi.
2. The Principal, Sant Gyaneshwar Model School, Lakhmi Enclave, Extended Lal Dora, Alipur , Delhi-36.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

**WWW.dfs.Delhigovt.nic.in**

NA

**INSPECTION REPORT**

1. Name & address of the building : Sant Gyaneshwar Model School located at Lakhmi Enclave, Extended Lal Dora, Alipur, Delhi-110036.
2. Type of Occupancy : Educational
3. Building Comprised : Two Blocks interconnected (Gr. + Two & Gr.+ Three upper floors)
4. Type of Case : Addition/Alteration
5. Details of Previous NOC : F6/DFS/MS/School/2012/890 dated- 12/03/2012 for (Gr.+02 Upper floors)
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 15/09/2023
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers  
From the building side : Sh. Prem Singh Mann
10. Year of Construction : -----
11. Applicant's letter No. : Diary No. 2109 , Dated-21/04/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02 in each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	Block A- 1.5 m & 1.2 m Block B- 1.5 m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Block A- 01 Block B- 02	Block A- 02 Block B- 02	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	Block A- 1 m Block B- 1.20 m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	20	Provided	MR
	• Types	ABC/Co2	ABC/Co2	MR
	• IS marking	Yes	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	Block A- 02 Block B- 01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR

N-7

	• Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	-	-	-
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	-	-	-
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA

	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.	NA	NA	NA
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room	NA	NA	NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures under rules it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2012/890 dated 12/03/2012 under rule 35 of the Delhi Fire Service, Rules 2010.

*Ab*  
ADO(B.W.)  
18/9/23

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

*De (fo/22)*

*Ab*  
18/9

*C/S*  
19/9/2023

*Director*  
20/9/23

*ADP MW for fire safety*

*for sign plan*  
ADO(B.W.)  
21/9/23

*12/9/2023*

*19/9/23*