



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2023/School/ 633

Dated: 14/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Delhi Police Public School located at New Police Line, Kingsway Camp, Delhi-110009 comprised of 02 blocks, Ground floor & Ground plus first floor only owned/occupied by Delhi Police Public School was granted FSC by this department vide letter no. No.F6/DFS/MS/2017/WZ/1406 dated 22.09.2017. The premises was inspected by the officer concerned of this department on 01.09.2023 in presence of Mrs. Tarunima Roy (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class 'Group B Educational' with effect from 14.09.2023.... for a period of Valid up to 31.03.2026 subject to compliance of the conditions mentioned below:

Issued on ..14.09.2023... at New Delhi

(Atul Garg)

Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, Delhi Police Public School located at New Police lines, Kingsway Camp, Delhi-110009.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Delhi Police Public School at New Police lines, Kingsway Camp.  
Delhi-110009.
2. Type of Occupancy : Educational
3. Composition of building : 02 blocks ( Ground floor & Ground + first floor only)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2017/WZ/1406 Dated: 22.09.2017
6. Fire Safety directives letter No : Nil
7. Date of inspection : 01.09.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Mrs. Tarunima Roy ( Principal)
10. Year of Construction : 2004/2016
11. Applicant's letter No. : 1852/DPSS/NPL Dated- 24/08/2017

Plot Area- 1440sq.m		Covered Area:765m <sup>2</sup>		class rooms - 18nos	students - 617nos	Remarks MR/NMR
Minimum Standards on fire prevention and fire safety U/R 33		Requirement as per Rule 35 (6)	Provided at site			
1	Access to building	6m	6m	MR		
	• Road width	4.5m	4.5m	MR		
	• Gate width	NA	NA	NA		
	• Width of internal road	NA	NA	NA		
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>					
	a. Number of staircases	01	02	MR		
	• Upper Floors	NA	NA	NA		
	• Basements	NA	NA	NA		
	b. Width of staircases	1.50m	1.50m iron staircase & 1.40m	MR		
	• Upper Floors	NA	NA	NA		
	• Basements	NA	NA	NA		
	c. Protection of exits	NA	NA	NA		
	• Fire check door	NA	NA	NA		
	• Pressurization	NA	NA	NA		
d. No. of continuous staircases to terrace	NA	NA	NA			
e. Width of Corridor	NA	NA	NA			
f. Door Size	01m	01m	MR			
3	<b>Compartmentation.</b>					
	• Fire check door	NA	NA	NA		
	• Sealing of electrical shafts	NA	NA	NA		
	• Fire Rating of shaft door	NA	NA	NA		
	• Water Curtain	NA	NA	NA		
	• Fire Dampers	NA	NA	NA		
4	<b>Smoke Management System.</b>					
	• Basements	NA	NA	NA		
	• Upper floors	Required	Natural Ventilation	MR		
5	<b>Fire Extinguishers</b>					
	• Total numbers	12nos	36nos	MR		





14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>			
		N/A	N/A	N/A
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>			
		N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2017/WZ/1406 dated 22.09.2017.

Signature of the Inspecting Officer  
Name :- C.L. Meena  
Designation :- ADO RN

M.K. Chattopadhyay  
Dy. Chief Fire Officer (NWD)

5/9/2023  
6/9/2023  
4/10/2023

ADY EA