



c/13



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/2023/NDZ/ Sch/ 673

Dated: 26/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the L.R. Memorial Convent School located at T-134, Main Road, Tughmeer Pur, Delhi-110094, building comprised of Ground plus one upper Floor only owned / occupied by L.R. Memorial Convent School, was issued FSC vide letter No. F6/DFS/MS/2017/NDZ/1218 Dated 16/08/2017. The School building was re-inspected by the officer concerned of this department on 12/09/2023 in presence of Mr. Satvir Singh Mavi and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F16/Easte/CC/FS/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education and observed that the building is fit for occupancy class "Educational" (Group-B) with effect from 26/09/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 26/09/2023 at New Delhi by.

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE.

Copy to :-

1. The Manager, L.R. Memorial Convent School, T-134, Main Road, Tughmeer Pur, Delhi-94.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

- N/3
1. Name & address of the building: L.R. Memorial Convent School, T-134, Main Road, Tukhmeer Pur, Delhi-110094.
  2. Building is comprised of : Ground & One Upper Floor only
  3. Type of Occupancy : Educational
  4. Type of Case : Renewal
  5. Details of previous NOC : F6/DFS/MS/2017/NDZ/1218 Dated 16/08/2017
  6. Fire Safety directives Letter No.: Circular No. 3298-3398 Dated 01/03/2011
  7. Date of inspection : 12/09/2023
  8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
  9. Name and designation of Officer from the building side : Mr. Satvir Singh Mavi
  10. Year of Construction : 2006
  11. Applicant's letter No. : Nil dated 21/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Circular Requirements	Provided at Site	Remarks MR/N MR
1.	Access of building			
	• Road width	6 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 nos.	02 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 m	1.00m & 0.81m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 nos.	01 nos.	MR
	e. Width Of Corridor	1.50 m	1.50 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 nos.	05 nos.	MR
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR
	• IS marking	Required	Provided	MR

A  
old case

N/A

6.	First - Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A

A

9)

16.	Provision of Lifts.			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F6/DFS/MS/2017/NDZ/1218 Dated 16/08/2017 under circular No. 3298-3398 dated 01/03/2011 is recommended.

*Ashok*  
13/09/2023

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : D.O. (East Division)

*Sy CFO (NDZ)*

*C.F.O.*  
*Imp*  
19/09/23

*Director*  
21/9/2023

*D/Cell*

F.T.L letter is put up for signature please.

*Director*  
23/9/23

*Imp*  
22/9/2023