



CL/16

75
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2023/NDZ/ 674

Dated: 26 / 09 / 2023

FIRE SAFETY CERTIFICATE

Certified that the **Prahlad Modern School**, located at **Gali No. -04, Shahid Bhagat Singh Colony, Vill & Post Karawal Nagar, Delhi-110094**, building comprised of **Ground & One upper floor only**, owned / occupied by Prahlad Modern School, was issued FSC vide letter No. F6/DFS/MS/School/2018/NDZ/1253 Dt. 29/05/2018. The School building was re-inspected by the officer concerned of this department on **15/09/2023** in presence of **Mr. Ajit Singh** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E circular No. F16/Estate/CC/FS/2011/3298 to 3398 Dated 01/03/2011 and that the building is fit for occupancy class **"Educational" (Group-B)** with effect from 26 / 09 / 2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 26/09/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.

Copy to:-

1. The Manager, Prahlad Modern School, Gali No.-04, Shahid Bhagat Singh Colony, Karawal Nagar, Delhi-110094
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Prahlad Modern School, Gali No.-04,
Shahid Bhagat Singh Colony,
Vill & Post. Karawal Nagar, Delhi-110094.
2. Building is comprised of : Ground & 1st Floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2018/NDZ/1253 Dt. 29/05/2018
6. Fire Safety directives Letter No.: F.16/Estate/CC/FS/2011/3298-3398 Dt. 01/03/2011
7. Date of inspection : 15/09/2023
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer
from the building side : Mr. Ajit Singh
10. Year of Construction : 2015
11. Applicant's letter No. : Nil dated 21/08/2023

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular Requirements	Provided at Site	Remarks
1	Access to building			
	• Road width	06 m	06 m	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	➤ Upper Floor	01	02	M/R
	➤ Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.50 m	1.32 m & 1.25 m	M/R (on accepted)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.50 m	1.50 m	M/R
	f. Door size	1.00 m	1.00 m	M/R
3	Compartmentation			
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	04	06	M/R
	• Types	ABC & Co2	ABC & Co2	M/R
	• IS Marking	ISI Marked	ISI Marked	M/R

(Handwritten signature)

6	First-aid-Hose Reels			
	• Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	N/A	N/A	N/A
	• Number of Hydrants per Floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	N/A	N/A	N/A

201

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	
18	Refuge Area			N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required in Director of Education Circular No. F.16/Estate/CC/FS/2011/3298-3398 Dt. 01/03/2011, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2018/NDZ/1253 Dt. 29/05/2018 is recommended to be renewed.

Ashok Kumar Jaiswal
15/9/2023

Signature of the Inspecting Officer
Name: Ashok Kumar Jaiswal
Designation: D.O. (East. Div.)

~~Dy. C.F.O. (NDZ)~~

King
19/9/23

~~c.f.o.~~
11/9/2023

~~Director~~
21/9/23

~~Dy. C.F.O.~~

F.T.L. letter is put up for sign. pl.

~~Director~~
23/9/23

ART
22/9/2023