



No.F6/DFS/MS/NDZ/2023/EH/290

Dated: 25/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Q VIN LA A Unit of Vayu Felicity Cuisine and Lounge Private Limited, Plot No. B-20, 21, 126/10 Third floor, Guru Nanak Pura, Laxmi Nagar, Delhi -110092, running at Third floor only in a building comprised of Basement + Ground + 03 Upper floor, owned/occupied Q Vin La a Unit of Vayu Felicity Cuisine and Lounge Private Limited have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 12/09/2023 in the presence of Mr. Harsh Vardhan (Owner) and found that the building/premises is fit for occupancy class "Assembly" (Group D) Eating House (Restaurant at Third floor only) and valid up to 31/03/2026 (Three years) in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 25/09/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c @

Copy to:-

1. Mr. Harsh Vardhan, Q Vin La a Unit of Vayu Felicity Cuisine and Lounge Private Limited located at Plot no. B 20, 21, 126/10 third floors, Guru Nanak Pura, Laxmi Nagar, Delhi -110092.
2. Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi-24 w.r.t. - MHA portal ID - 2023081814786 dated-26/08/2023.

1. management.
2. The trained fire fighting staff should be available round the clock.
3. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
4. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
7. Basement shall be used as per NBC/UBBL.
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

1101
INSPECTION REPORT

1	Name & address of the building	Q Vin La a Unit of Vayu Felicity Cuisine and Lounge Private Limited Plot No. B 20, 21, 126/10, Third floor, Guru Nanak Pura, Laxmi Nagar, Delhi-110092.		
2	Building is comprised of	Basement + Ground + 03 upper floors only. (Eating House is 3 rd Floor only)		
3	Type of occupancy	Eating House (Restaurant)		
4	Type of case	New Case		
5	Details of previous FSC	Nil		
6	Fire safety direction letter no.	NBC Part-IV		
7	Date of inspection	12.09.2023		
8	Name of the inspecting officers	A.K Jaiswal (DO/ED) & Yashwant Singh Meena (ADO/LN)		
9	Name of the designation of officer From the building side	Mr. Harsh Vardhan (Owner)		
10	Year of construction	2015		
11	Applicant's letter no	Application no. 2023081814786 dated-26/08/2023		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
a	Road width	6.0 mtrs.	6.0 mtrs	MR ✓
b	Gate width	NA	NA	NA
c	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	1.50 mtrs	1.60 mtrs. & 2.0 mtrs.	MR ✓
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	Required	Provided	MR
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	01 no.	02 nos.	MR
E	Width of corridor	1.50 mtrs	1.60 mtrs	MR ✓
F	Door size	1.50 mtr x 02	1.50 mtr x 02	MR ✓
3	Compartmentation			
a	Fire check door	Required	Provided	MR ✓
b	Sealing of electrical shafts	Required	Provided	MR ✓
c	Fire rating of shaft door	NA	NA	NA
d	Water curtain	NA	NA	NA
e	Fire dampers	NA	NA	NA
4	Smoke Management System.			
a	Basement	NA	NA	NA
b	Upper floor	Required	Provided	MR

(W) ✓

5.	Fire Extinguisher			
a	Total numbers	06 nos.	08 nos.	MR ✓
b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
c	ISI marking	ISI marked	ISI marked	MR ✓
6	First-aid-Hose Reels.			
a	Total numbers of each floor	01 nos.	01 nos.	MR
b	Length of hose reel hose	30 mtr.	30 mtr.	MR
c	Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
a	Type of detectors	Smoke	Provided	MR
b	Location of main panel	Third floor	Provided	MR
c	Location of repeater panel	NA	NA	NA
d	Alternate source of power	Required	Provided	MR
e	Hooter	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
a	Basement	NA	NA	NA
b	Upper floors	NA	NA	NA
c	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
a	Size of riser	100 mm	100 mm	MR ✓
b	Number of hydrants per floor	01 no.	01 no.	MR
c	Hose Box	01 no.	01 no.	MR ✓
12	Yard Hydrants.			
a	Total number of hydrants	NA	NA	NA
b	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
A	Terrace Level			
a	Discharge of main Pump	2280 LPM	2280 LPM	MR ✓
b	Head of Main Pump	60 mtr	60 mtr	MR
c	Number of main pumps	1 nos.	1 nos.	MR
d	Jockey pump out put	180 LPM	180 LPM	MR
e	Jockey pump head	60 mtr	60 mtr	MR ✓
f	Standby pump out put	2280 LPM	2280 LPM	MR
g	Standby pump head	60 mtr	60 mtr	MR ✓
h	Auto starting /manual stopping	Required	Provided	MR
i	Pump House Access	Required	Provided	MR
B	Ground Level			
a	Discharge of pump	NA	NA	NA
b	Head of the Pump	NA	NA	NA
c	Power supply	NA	NA	NA
d	Auto Starting of pump	NA	NA	NA

Q Vin La a Unit of Vaya Felicity Cuisine and Lounge Private Limited located at Plot no. B 20, 21, 126, by 10 Third floor Guru Nanak Pura, Laxmi Nagar, Delhi -110092.

W A

Q Vin La a Unit of Vaya Felicity Cuisine and Lounge Private Limited located at Plot no. B 20, 21, 126, by 10 Third floor
Guru Nanak Pura, Laxmi Nagar, Delhi -110092.

14	Captive Water Storage for Fire Fighting.			
a	Underground tank capacity	NA	NA	NA
b	Draw-off connection	NA	NA	NA
c	Fire service inlet	NA	NA	NA
d	Access to tank	NA	NA	NA
e	Overhead Tank capacity	1,00,000 Ltrs.	1,40,000 Ltrs.	MR ✓
15	Exit Signage.	Required	Provided	MR ✓
16	Provision of Lifts.			
a	Pressurization of Lift Shaft	NA	NA	NA
b	Pressurization of Lift lobby	NA	NA	NA
c	Communication in lift car	NA	NA	NA
d	Firemen's grounding switch	NA	NA	NA
e	Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
a	Total area	NA	NA	NA
b	Location	NA	NA	NA
19	Fire Control Room			
a	Detector system panel	NA	NA	NA
b	Flow switch panel	NA	NA	NA
c	PA system panel	NA	NA	NA
d	Battery backup	NA	NA	NA
e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

Signature of the Inspecting Officer
Name: - A.K.Jaiswal
Designation: - DO(ED)

Dy.CFO (NDZ)

— Instead of UGWS tank, the management has provided overhead tank of the requisite capacity.

— DO(ED) & ADO(LN) may be warned for putting/recommending the same without approval of Competent Authority
Submitted for 'A' please.

C.F/O. Mugh
19/9/2023
Director Mugh
20/9/2023

DO(ED) AKJ
21.9.2023

AKJ
18/09/23