



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F6/DFS/MS/Bnqt./2023/NDZ/ 38

Dated: 21/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Tru Hallmark Banquets Pvt. Ltd. running on ground floor, first floor and second floor only building comprised of basement, ground plus two upper floors located at Ground, first floor & second floor, PD Area Karkardooma Metro Station Delhi-110092, owned/occupied by Tru Hallmark Banquets Pvt. Ltd. was issued FSC vide letter No. F.6/DFS/MS/BNQT/2020/NDZ/341 dated 02/09/2020. The premises was inspected by the officers concerned of this department on dated 11/09/2023 in the presence of Mr. Kamal Arora and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the building/premises is fit for occupancy class "Assembly" Group 'D' valid up to 31/03/2026 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....21/09/2023.....at New Delhi by

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

To,

1. Mr. Kamal Arora
Tru Hallmark Banquets Pvt. Ltd.
Ground, 1st floor & 2nd floor at PD Area Karkardooma Metro Station, Delhi-110092
2. The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony, New Delhi
MHA ID 2021110725849

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Tru Hallmark Banquets Pvt. Ltd. at Ground, 1st floor & 2nd floor at PD Area Karkardooma, Metro Station, Block-A, Delhi-92
2. Building is comprised of : B+G+2 (Banquet is running at Gr., 1st & 2nd floor)
3. Type of Occupancy : Assembly Building
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/BNQT/2020/NDZ/341 dt 02/09/2020
6. Fire Safety direction letter No. : F.6/DFS/MS/BP/2011/2390 dated 30/09/11
7. Date of Inspection : 11/09/2023
8. Name of the Inspecting officers : DO (ED) & ADO (Shd.)
9. Name and designation of Officer from the building side : Mr. Kamal Arora
10. Year of Construction : 2011
11. Applicant's email ID : 2021110725849 dated 25/08/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> Road width 	06 mtr	08 mtr	MR
	<ul style="list-style-type: none"> Gate width 	4.5 mtr	4.5 mtr	N/A
	<ul style="list-style-type: none"> Width of internal road 	06 mtr	06 mtr	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor 	02 nos.	04 nos.	MR
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor 	1.5 m	1 no. of 02 mtr, ✓ 2 no. of 1.50 mtr & ✓ 1 no. of 1.20 mtr ✓	MR
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization 	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr	02 mtr ✓	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> Water curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire dampers 	Required	Provided	MR
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> Upper floor 	12 a/c per hour	Provided	MR
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	24 nos.	30 nos.	MR
	<ul style="list-style-type: none"> Types 	ABC /CO ₂	ABC /CO ₂	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	MR

R. A

N/22

06	First-Aid-Hose Reels.			
	Total numbers on each floor	03 nos.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat or Smoke	Provided	MR
	• Location of main panel	Ground floor	Provided	MR
	• Location of repeater panel	Concourse	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter	Staircase & Hall	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	03 nos.	Provided	MR
	• Hose box	03 nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	02 nos.	03 nos.	MR
	• Hose box	02 nos.	03nos.	MR
13	Pumping Arrangements.	Common with Metro Station		
	➤ Ground Level			
	• Discharge of main pump	2850 LPM	2850 LPM	MR
	• Head of main pump	70m	70m	MR
	• Number of main pumps	02 no.	02 no.	MR
	• Jockey pump out put	180 Lpm	180 Lpm	MR
	• Jockey pump head	70m	70m	MR
	• Standby pump out put	2850 Lpm	2850 Lpm	MR
	• Standby pump head	70m	70m	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	1,00,000 Ltrs.	2,00,000 Ltrs.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 Ltr.	Provided	MR
15	Exit Signage.	Required	Provided	MR

Q. X W /

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	Provided for Metro Station		
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	Required For HT/LT Panels	Provided	MR

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The FSC vide letter no. F.6/DFS/MS/BNQT/2020/NDZ/341 dated 02/09/2020 under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
12/09/2023.
Signature of the inspection Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

A.K. Jaiswal
12/09/2023
Signature of the inspection Officer
Name :- A.K. Jaiswal
Designation :- D.O (ED)

Dy. CFO (A.D.2)

Ring
14/09/23

C.F.O. *Mugh*
15/9/2023

Director *Mugh*

DO/ED
19.9.2023

A.D.O (Shd)

Sir, F.T. letter is put up for your kind signature pl.

Deepak
20/09/2023.