

2/04

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2023/ School | 670

Dated: 22/09/2023

FIRE SAFETY CERTIFICATE

Certified that Wisdom Playgro School, Located at Ground & 1st floor Plot No-36, Hari Vihar, Gali No. 2, Kakrola, Delhi-110078 in a building comprised of Ground+03 Upper Floors owned/ occupied by Wisdom Playgro have complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 and verified by the officer concerned of this department on 14/09/2023 in the presence of Sh. Kuldeep Gupta (Principal) and found that the building is fit for occupancy class B "Educational building" (AT Ground and 1st Floor only) with effect from 22/09/2023 for a period of three year.

Issued on 22/09/2023 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service.

Copy to:

1. Sh. Kuldeep Gupta (Principal) Wisdom Playgro School, Located at Ground & 1st floor Plot No-36, Hari Vihar, Gali No. 2, Kakrola, Delhi-110078.
2. Directorate of Education Old Secretariat Delhi - 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

211

INSPECTION REPORT

1. Name & address of the building: Wisdom Playgro School, Located at Ground & 1st floor Plot No-36, Hari Vihar, Gali No. 2, Kakrola, Delhi-110078.
2. Type of Occupancy : Educational (**At Ground +One Upper Floors Only in a building comprised of G+03 Upper Floors.**)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE Circular 3298 -3398 Dated 01/03/2011
6. Date of inspection : 14-09-2023
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side :Sh. Kuldeep Gupta (Principal)
9. Year of Construction :
10. Applicant's letter No. :nil dated 01/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular 3298-3398 Dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	09 mtrs Provided	MR
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 No's	02 No's	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	2x 1.5m Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	100cm	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR

[Handwritten signature]

N12

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos. ABC & CO ₂ ISI marked	04 Nos. Co ₂ & ABC Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA NA NA	NA NA NA	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
15	Exit Signage	NA	NA	NA

21

h

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADO/DWR

DO/SW
 Please mention the occupancy of upper floor also
 14/9/23

ADO (Dwaraha)

As mentioned at H/1 ^{2nd} ground
 & 1st floor is being used as school &
 Upper floors are vacant.
 Submitted Please

DO/SW 14/9/23

1/10
 14/9/23