



C-25
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/EH/2023/NDZ/ 297

Dated: 27/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Dominos Pizza (Jubilant Foods Works Ltd.) running at ground floor of the building comprised of two basements, ground plus two upper floors located at G-11, Ground floor, 29-31, Aggarwal Fun City Mall, Unity One, CBD Shahdara, Delhi-110032, owned/occupied M/s Jubilant Foods Works Ltd. was issued FSC vide letter No. F.6/DFS/MS/EH/2020/NDZ/162 dated 19/11/2020. The premises was re-inspected by the officers concerned of this department on dated 19/01/2023 in the presence of Ms. Aradhana (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly" with effect from 27/9/2023 is valid upto 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 27/09/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To,

Sh. Yunus Khan,
M/s Jubilant Foods Works Ltd. at G-11, Ground floor, 29-31,
Aggarwal Fun City Mall, CBD Shahdara, Delhi-110032

Copy to:-

The Joint Commissioner of Police (Lic.),
1st Floor Police Station, Defense Colony, New Delhi
MHA ID- 2023090315565 dated 04/09/2023

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

116

1. Name & address of the building : Dominos Pizza (Jubilant Foods Works Ltd.)
G-11, Ground floor, 29-31, Aggarwal Fun City Mall,
Unity One, CBD Ground, Shahdara Delhi
2. Building is comprised of :02 basement, ground plus two upper floors
(Restaurant is running ground floor only)
3. Type of Occupancy :Restaurant (Assembly)
4. Type of Case :Renewal
5. Details of Previous NOC letter :F.6/DFS/MS/EH/2020/NDZ/162 dated 19/11/2020
6. Fire Safety directive letter No :NBC Part IV
7. Date of Inspection :18/09/2023
8. Name of the Inspecting officers :DO(ED), A.K. Jaiswal& ADO(Shd.), Deepak Kumar
9. Name and designation of Officer
from the building side :Mr. Aradhana (Manager)
10. Year of Construction :2005
11. Applicant's letter No :2023090315565 dated 04/09/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12mtr.	26mtr.	MR
	• Gate width	4.50mtr.	05mtr.	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	2.5 mtr	MR
	f. Door Size	02 mtr.	02 nos. (02 mtr&1.50mtr)	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	03nos.	03nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

2. A

117

06	First-Aid-Hose Reels.			
	Total numbers	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	Control Room	Provided	MR
	• Location of repeater panel	Security Room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter	Different Location	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	Provided	N/A
	• upper floor	N/A	Provided	N/A
	• sprinkler above false ceiling	N/A	Provided	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	04 nos.	MR
	• Hose box	01 nos.	04 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	01 nos.	N/A
	• Hose box	N/A	01 nos.	N/A
13	Pumping Arrangements.			
	➤ Ground Level	Common with Mall		
	• Discharge of main pump	2280 lpm	2280 lpm	MR
	• Head of main pump	60mtrs	60mtrs	MR
	• Number of main pumps	01nos	01nos	MR
	• Jockey pump out put	450 lpm	450 lpm	MR
	• Jockey pump head	60mtr	60mtr	MR
	• Standby pump out put	2280 lpm	2280 lpm	MR
	• Standby pump head	60 mtr	60 mtr	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	Common with Mall			
	• Underground tank capacity	N/A	2,00, 000 ltrs	MR
	• Draw-off connection	N/A	Provided	MR
	• Fire service inlet	N/A	Provided	MR
	• Access to tank	N/A	Provided	MR
	• Overhead tank capacity	20,000 ltr	25,000 ltr	MR
15	Exit Signage.	Required	Provided	MR

[Handwritten signature and initials]

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
17	Standby Power Supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/EH/2020/NDZ/162 dated 19/11/2020 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
 Signature of the Inspecting Officer
 Name : Deepak Kumar
 Designation : A.D.O. (SHD)
 20/09/2023.

A.K. Jaiswal
 Signature of the Inspecting Officer
 Name : A.K. Jaiswal
 Designation : D.O. (East)
 20/09/2023

Dy. CFO (NDZ)

Deep
 21/09/23

CFO. *Naresh*
 22/9/2023

Director *[Signature]*
 25/9/23

DD/Kant
 26/9/2023

Abol Shakti Sir, F.T. Letter is put up for your kind signature pl. *[Signature]*