



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-44



No. F6/DFS/MS/2023/School/ 698

Dated: 29/09/2023

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary School located at Mukharjee Nagar, Old Delhi-110009 comprised of 03 Blocks, two block comprised of ground floor & one block comprised of ground + first floor only owned/occupied by M.C. Primary School, was granted FSC by this department vide letter No.F6/DFS/MS/2020/403 dated 07.10.2020. The premises was inspected by the officer concerned of this department on 16.09.2023 in presence of Smt. Subhadra Kumari (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational" with effect from .29/09/2023.. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ..29/09/2023.... at New Delhi

(Ajul Garg)
Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, M.C. Primary School located at Mukharjee Nagar, Old Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M. C. Primary School at Mukharjee Nagar Old Delhi-.110009.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 03 blocks (02 block -Ground floor & 01 Block G + first floor only)
5. Details of previous NOC : F6/DFS/MS/2020/403 dated: 07.10.2020
6. Fire Safety directives letter No : Nil
7. Date of inspection : 16.09.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Smt. Subhadra Kumari (Principal)
10. Year of Construction : 1992
11. Applicant's letter No. : Online E-mail ID Dated-09.09.2023


	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	4.5m	3.40m	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m	1.35m & 1.40m	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	NA	NA	NA
f. Door Size	01m	1.20m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			


N/24

	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
15	Exit Signage.	NA	N/A	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A.	N/A



The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2020/403 dated 07.10.2020.


 Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN


 M.K. Chattopadhyay
 Dy. Chief Fire Officer (WZ)

JCF
 24/07/2023


 22/8

 22/9/2023


 ADO/RN