



No F 6 / DFS / MS / 2023 / School / WZ / 687

Dated: 29/09/2023

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Agarsain Public School** located at **Ashok Vihar, Phase-IV, Delhi-110052** comprised of **Basement, Ground plus Three upper floors** owned/occupied by **Maharaja Agarsain Public School** was issued FSC by this department vide letter No F6 /DFS/MS/WZ/2020/58 dated 14.02.2020. The premise was re-inspected by the officer concerned of this department on 14.09.2023 in the presence of **Smt. Alka Sahni (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with NBC/BBL 1983 and that the building/ premise is fit for occupancy **Group B Educational** with effect from 29/09/2023 for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/09/2023 at New Delhi, by


 (Atul Garg)
 Director
 Delhi Fire Service
 OUA

Copy to :-

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Maharaja Agarsain Public School located at Ashok Vihar Phase-IV, Delhi-110052.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. Basement shall not be used for classroom purpose and Auditorium.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N20

INSPECTION REPORT

1. Name & address of the building : Maharaja Agarsain Public School located at Ashok Vihar Phase-IV, Delhi-110052.
2. Type of Occupancy : Educational
3. Building Comprised of : Basement, Ground plus three upper floors .
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/WZ/2020/58 Dated 14/02/2020
6. Fire Safety directives letter No : NA
7. Date of inspection : 14/09/2023
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Smt. Alka Sahni (Principal)
10. Year of Construction : 1995
11. Applicant's letter No. : MAPS/2023 dated 22/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (VI) of DFS Rules 2010.	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	Required	03 m	MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	03	04	MR
	b. Width of staircases			
	• Upper Floor	1.50 m each	2×1.6 m & 2×1.5 m	MR
	• Basements	1.50 m each	2×1.5 m & 2×1.3 m	MR(old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace			
		02	Provided	MR
	e. Width of Corridor			
		2 m	Provided	MR
	f. Door Size			
		1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	27	Provided	MR
	• Types	ABC/Co2 Type	Provided	MR

(Handwritten mark)

(Handwritten mark)

N-21

	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	05	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			

22

+

N-22

MR	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14. Captive Water Storage for fire fighting				
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16. Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18. Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19. Fire Control Room				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The school management had rectified the shortcomings issued vide letter number F6/DFS/MS/School/WZ/2023/248 dated 17/05/2023.

Note: Basement shall not be used for classroom purpose and Auditorium.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/WZ/2020/58 dated 14/02/2020 under rule 35 of Delhi Fire Service Rules, 2010.

151
12/9/2023

Dy. C.O. (WZ)

29/9

19/9/2023

Director

ADO (WZ)
18/9/23

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.