

C-29



FORM 'H'  
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
 [Refer sub - rule (1) of rule 35]  
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
 NEW DELHI



No.F6/DFS/MS/2023/School/699

Dated: 29/09/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M.C Primary School, Basti Regar, Arya Samaj Road, Karol Bagh, New Delhi-110005.(School ID-2160061) comprised of Ground Floor have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 29/08/2023 in the presence of Ms. Amita (Incharge) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 29/09/2023 for a period of three years.

Issued on 29/09/2023.. at New Delhi by.

  
 (Anul Garg)  
 Director  
 Delhi Fire Service. 

Copy to:

1. The Principal, M.C Primary School, Basti Regar, Arya Samaj Road, Karol Bagh, New Delhi-110005.(School ID-2160061)
2. Directorate of Education Old Secretariat Delhi - 110054

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

2-16

## INSPECTION REPORT

1. Name & address of the building: M.C Primary School, Basti Regar, Arya Samaj Road, Karol Bagh, New Delhi-110005 (School ID-2160061).
2. Type of Occupancy : Educational Ground floor only
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 29/08/2023
7. Name of the Inspecting Officer : Udai vir singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Ms. Amita (Incharge)
9. Year of Construction : 1934
10. Applicant's letter No. : Nil Dated - 11/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/BC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtrs	Provided	MR
	• Road width	Accessible	On road	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	NA	NA	NA
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	01 mtr	106cm	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	2 nos.ABC or CO <sub>2</sub>	5 Provided	MR
	• Types	ISI marked	Provided	MR
	• IS marking		ISI marked	MR

h

2-77

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

D. W

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	ABC Fire Extinguisher Near Electric		MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

**Note:- The school is having two blocks comprised of Ground Floor & Ground + 2 Upper Floors. The FSC is recommended for Ground floor block only**

~~Signature of the Inspecting Officer~~  
 Name Uday Vir Singh  
 Designation ADP/1007K

D.O (S.W)  
20/9/23

CGO (S2)  
21/9/2023

Director  
21/9/23  
pm

Sir PP letter is put up for sig b/c

DIRECTOR  
21/10/23

22/9/23