

C 23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/695

Dated: 29/09/2023

FIRE SAFETY CERTIFICATE

Certified that the M.C Primary School, Kazipur, New Delhi-110073 comprised of ground plus one upper floor owned/occupied by M.C.D Primary School having total 12 rooms (Including Class Rooms, Offices & Hall Etc.) was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2020/SZ/320 dated 01/09/2020. The school building was re- inspected by the officer concerned of this department on 21/09/2023 in the presence of Smt.Usha Rani (Principal) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....29/09/2023..... at New Delhi.

(AFO GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Principal,
M.C Primary School,
Kazipur, New Delhi-110073
2. Director of Education,
M.C.D, Civic Centre,
Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry

N/17

INSPECTION REPORT

1. Name & address of the building : M.C Primary School, Kazi Pur, New Delhi-110073
2. Building comprised of : Ground plus one upper floor.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC. : F.6/DFS/MS/School/2020/SZ/320 dated 01/09/2020
6. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7. Date of inspection : 21/09/2023
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Usha Rani (Principal)
10. Year of Construction : 2010
11. Applicant's letter No. : Nil dated 14/09/2023

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirement as per FSC dt. 01.09.2023 | Provided at site | Remarks MR/NMR |
|--------|---|--|---|---------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Accessible 06 mtrs 4.5 m N/A | 06 mtrs Directly accessible from road N/A | MR N/A N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 02 no.'s N/A | 02 no.'s N/A | MR N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | 1.50 & .75 m N/A | 1.30 m each N/A | MR N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | N/A N/A | N/A N/A | N/A N/A |
| | d. No. of continuous staircases to terrace | | | |
| | | N/A | N/A | N/A |
| | | 1.50 m | 2.35 m | MR |
| | e. Width of Corridor | | | |
| | | 1.0 m | 1.15 m (double door) | MR |
| | f. Door Size | | | |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> • Upper floors | Required | Natural Ventilation provided | MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 04, No's ABC/CO ₂ type ISI marked | Provided Provided ISI marked | MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |

Handwritten marks at the bottom of the page.

| | | | | |
|-----|---|-----|----------|-----|
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | | | |
| | | N/A | N/A | N/A |
| 9. | Public Address System | | | |
| | | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | N/A | N/A | N/A |
| | • Ground Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | ➤ Discharge of pump | N/A | N/A | N/A |
| | ➤ Head of the pump | N/A | N/A | N/A |
| | ➤ Power Supply | N/A | N/A | N/A |
| | ➤ Auto Starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | ➤ Draw-off connection | N/A | N/A | N/A |
| | ➤ Fire service inlet | N/A | N/A | N/A |
| | ➤ Access to tank | N/A | N/A | N/A |
| | • Overhead Tank capacity | N/A | N/A | N/A |
| 15. | Exit Signage. | | | |
| | | N/A | Provided | N/A |
| 16. | Provision of Lifts. (No Lift) | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | | | |
| | | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |

Handwritten marks and signatures at the bottom of the page.

N/19

| Fire Control Room | | | | |
|---|---|-----|-----|-----|
| <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2020/SZ/320 dated 01/09/2020 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

R.K. Yadav
28/9/2023

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

M 26/9/23
Cfo (S2) *[Signature]*
26/9/2023
Director *[Signature]*
27/9/23
[Signature]