

C-24



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2023 / School / WZ / 686

Dated: 29/09/2023

FIRE SAFETY CERTIFICATE

Certified that Neo Arts Co-ed Middle School located at Shalimar Bagh, Delhi-110088 comprised of Ground Floor only owned/occupied by Neo Arts Co-ed Middle School was issued FSC by this department vide letter No F6 /DFS/MS/2017/WZ/1770 dated 08.12.2017. The premises was inspected by the officer concerned of this department on 20.09.2023 in the presence of Smt. Shital Gupta (Headmistress), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group B Educational** with effect from 29/09/2023... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 29/09/2023.. at New Delhi, by

(Atul Garg)

Director

Delhi Fire Service

Atul

Copy to :-

1. The Director, Education, Old Secretariat , Delhi.
2. The Principal, Neo Arts Co-ed Middle School, Shalimar Bagh, Delhi-88.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on

WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Neo Arts Co-ed Middle School, Shalimar Bagh, New Delhi-110088.
2. Type of Occupancy : Educational
3. Building Comprised : Ground Floor Only.
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/2017/WZ/1770 Dated-08/12/2017
6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
7. Date of inspection : 20/09/2023
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers
From the building side : Smt. Shital Gupta (Headmistress)
10. Year of Construction : 2016
11. Applicant's letter No. : E Mail id , Dated-15/09/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided with door frame	MR(old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	02	Provided	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

Rv

nr/b

	<ul style="list-style-type: none">• Alternate source of power	NA	NA	NA
	<ul style="list-style-type: none">• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none">• Basement• Ground Floor• Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none">• Ground Level			
	➢ Discharge of main Pump	NA	NA	NA
	➢ Head of Main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey Pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Starting/Manual Stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	<ul style="list-style-type: none">• Terrace level	-	-	-
	➢ Discharge of pump	NA	NA	NA
	➢ Head of the pump	NA	NA	NA
	➢ Power Supply	NA	NA	NA
	➢ Auto Starting of pump	-	-	-
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none">• Underground tank capacity	NA	NA	NA
	➢ Draw-off connection	NA	NA	NA
	➢ Fire service inlet	NA	NA	NA
	➢ Access to tank	NA	NA	NA
	<ul style="list-style-type: none">• Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none">• Pressurization of Lift Shaft• Pressurization of Lift lobby• Communication In lift Car• Fireman's Grounding Switch	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none">• Lift Signage	NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

	<ul style="list-style-type: none"> ▷ Total Area ▷ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Battery backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01.03.2011 it is recommended to renew the FSC issued vide letter no. F6/DFS/MS/2017/WZ/1770 dated 08/12/2017.

~~Dr (fo) (02)~~

Sign in DFA then put up.

~~Ado (Bansari)~~
20/9/23

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/BW

~~Dr~~
20/9

~~Ado (Bansari)~~
Adeful done
~~Ado (Bansari)~~
20/9/23

~~Dr (fo) (02)~~

~~Dr~~
21/9

~~Dr~~
21/9/2023

~~Director~~
20/9/23

~~Ado / BW~~

~~Ado~~

FO
Dated: 21/9/2023