

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2023/ 460

Dated:-03/10/2023

FIRE SAFETY CERTIFICATE

Certified that **Bank of Baroda** located at **16, Sansad Marg, New Delhi**, comprised of **Basement + Ground + 13 upper floors**, was earlier granted FSC by this department vide letter No. **F.6/DFS/MS/GH/NDZ/2019/186** dated **13/04/20**. Now, the premises was re-inspected by the officers concerned of this department on **14/09/23** in the presence of Sh. Praveen, Fire Safety Officer and found that the said **business building** has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class- **Business** with effect from **03/10/2023**...for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 03/10/2023 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service


Copy to:-

1. The Chief Architect, NDMC Palika Kendra, New Delhi.
2. Sh. B.S Gupta, Dy. General Manager – DZH, Bank of Baroda, 16, Sansad Marg, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building : Bank of Baroda Building, 16, Sansad Marg, New Delhi.
2. Type of occupancy : Business Building
B + Gr. + 13 upper floors
3. Type of case:- : Renewal (12 point inspection)
4. Details of previous FSC : F.6/DFS/MS/GH/NDZ/2019/186 dated 13/04/20
5. Fire safety directives No. : F6/DFS/MS/84/479 dated 28/06/1984
6. Date of inspection:- : 14/09/23
7. Name of the inspecting officer : Sh. Rajinder Atwal DO/CD & Sh. Ravinder Singh ADO/CC
8. Name & designation of officer
From the building side : Sh. Praveen Kumar, Fire safety Officer
9. Year of construction : 1986
10. Applicant's letter No : ZO:NDZ:SEC:2023-24/601 Dated 01/09/19.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Approach to Building			
	1) Road width	6 mtr.	6 Mtr.	MR
	2) Gate width	06 mtr.	6 Mtr.	MR
	3) Width of internal road	N/A	06 mtr. one side only	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	01	MR
	2. Basements	02	02	MR
	B. Width of staircase			
	1. Upper floors	1.25 mtr.	01 Nos. 1.4m B to 2 nd floor & 01 Nos. ground to 13 upper floor	MR
	2. Basements	1.25 mtr.	1.4 & 1.5 mtr.	MR
	C. Protection of exits			
	1. Fire check door	N/A	Provided	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	NA	NA	NA
	F. Door size	NA	NA	NA
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Mechanical	MR
	2) Upper floors	12 ACPH	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	40	45	MR
	2) Types	ABC & CO2, WCo2	Provided	MR

W D

N/26

	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Heat & Smoke	Provided	MR
	2) Location of main panel	Main Exit	Main Exit	MR
	3) Location of repeater panel	Floor wise	Provided	MR
	4) Alternate source of power	Yes	Provided	MR
	5) Hooter's Location	Each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box each floor	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM ✓	MR
	b) Head of main pump	63 mtr.	63 mtr. ✓	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put	180 LPM	180 LPM ✓	MR
	e) Jockey pump head	63 mtr.	63 mtr.	MR
	f) Stand by pump output	1850 LPM	1850 LPM	MR
	g) Stand by pump head	63 mtr.	63 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	2,00,000 ltr. ✓	2,00,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR

✓ ✓ ✓

	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	Provided	N/A
	Total area location	N/A	Provided	N/A
19.	Fire Control Room	N/A	Provided	N/A
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & Co ₂			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Further, the following points are not required in 12 points inspection, whereas in previous FSC inspection Performa same have been mentioned, however, same are not provided at the site. If approved, we may exempt the same.

1. Pressurization of staircases and lift lobby & shaft.
2. Sprinklers system at upper floors.

In view of the deemed compliance of the 12 minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no F.6/DFS/MS/GH/NDZ/2019/186 dated 13/04/20, under 12 points. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Rajinder Atwal
21/9/23
Name: - Rajinder Atwal
Designation: - DO (CD)

Signature of the Inspecting Officer

Ravinder Singh
21/9/23
Name: - Ravinder Singh
Designation: - ADO (CC)

Dy. C.F.O. (NDZ)

Rino
21/9/23

C.F.O.

High
21/9/2023

Director
21/9/23

ADU/L