

C-32

FORM 'H'  
 FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
 [Refer sub - rule (1) of rule 35]  
 GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
 HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
 NEW DELHI

No.F6/DFS/MS/SZ/2023/School/705

Dated: 04/10/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Sant Public School, Located at CD-127, Mahavir Enclave, New Delhi-110045, comprised of Ground Floor, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/142, dated 07/04/2020. The premises was re inspected by the officer concerned of this department on 22/09/2023 in the presence of Mr.Vijay Kumar(Owner) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 and that the building is fit for occupancy class B "Educational building" with effect from 04/10/2023 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 04/10/2023..... at New Delhi by.

  
 (Abul Gaig)  
 Director  
 Delhi Fire Service.  
 o/c  
3/10/23

Copy to:

1. Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Sant Public School, Located at CD-127, Mahavie Enclave, New Delhi-110045.

**Following fire safety directives must be adhered to:-**

- 1 School is running at Ground floor in building comprised of Ground +1 Upper Floor & 1<sup>st</sup> floor is used by owner as residence.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



N/16

**INSPECTION REPORT**

1. Name & address of the building: Sant Public School, Located at CD-127, Mahavie Enclave, New Delhi-110045.
2. Type of Occupancy : Educational Ground Floors only (1<sup>st</sup> Floor Residence)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/142, dated 07/04/2020
5. Fire Safety directives Letter No. : . Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 22/09/2023
7. Name of the Inspecting Officer : Udai vir singh ADO (DVK)
8. Name and designation of Officer  
from the building side : Mr. Vijay Kumar (Owner)
9. Year of Construction :  
10. Applicant's letter No. : SPS/23 Dated - 15/09/2023

No. of Students= 45
No. of class rooms= 05
Plot area=166 sqmtr
Covered area=166 sqmtr

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/12, N/13 & N/14	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtrs	Provided	MR
	• Road width	Accessible	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	NA	02 Nos.	NA
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	80 cm & 75 cm	NA
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1.5m	160cm	MR
	e. Width Of Corridor	01 mtr	83cm	MR(Being old case)
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	01 nos.ABC or CO <sub>2</sub> for every 300 sq mtr	Provided	MR
	• Types	ISI marked	Provided	MR
	• IS marking	ISI marked	ISI marked	MR

*(Handwritten signature)*



11/17

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

16 17

18.	Refuge Area			
	➤ Total area	NA		
	➤ Location	NA	NA	NA
19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;		ABC Fire Extinguisher Near Electric	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2020/SZ/142; dated 07/04/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

~~Signature~~  
25/9/23

Signature of the Inspecting Officer  
Name Uday Vir Singh  
Designation ADP/DCU

DD/SCU

26/9/23

CFD (S2)

26/9/2023

Director  
27/9/23  
Aay DWR