

C16

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SCHOOL/2023/709

Dated: 04/10/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Ramjas Senior Secondary School No. 2, Located at Anand Parbat, New Delhi – 110005 having 02 blocks, 1st block comprised of G + 1UF & 2nd block comprised of Ground floor only, was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2015/SZ/106, dated 21/01/2015. The premises was re inspected by the officer concerned of this department on 20/09/2023 in the presence of Mr. Virender Parmar (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 and that the building is fit for occupancy class B "Educational building" with effect from 04/10/2023 for a period of **three years**, subject to compliance of the conditions printed as under.

Issued on ..04/10/2023.. at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
o/c

Copy to:

1. Mr. Virender Parmar (Principal) Ramjas Senior Secondary School No. 2, Anand Parbat, New Delhi – 110005.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/13

INSPECTION REPORT

1. Name & address of the building: Ramjas Senior Secondary School No. 2, Located at Anand Parbat, New Delhi - 110005.
2. Type of Occupan : Educational 02 Blocks (BL-1= G + 1UF) & (BL-II= Ground floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2015/SZ/106, dated 21/01/2015
5. Fire Safety directives Letter No. : Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 20/09/2023
7. Name of the Inspecting Officer : Udai vir singh ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Virender Parmar (Principal)
9. Year of Construction : 1917
10. Applicant's letter No. : 608, dated - 18/08/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9,N/10,N/11	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	9m Provided	MR
	• Gate width	Accessible	Provided	MR Old Case
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr each	2x150cm Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	01 mtr	112cm Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation provided	MR

[Handwritten signature]

N/14

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos.ABC & CO ₂ ISI marked	Provided	MR
			Provided	MR
			ISI marked	MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	Required	NA	NA
			Provided	MR

16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F.6/DFS/MS/School/2015/SZ/106, dated 21/01/2015 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Ver Singh
 Designation Inspector

[Signature]
 20/9/23

[Signature]
 22/9/2023

[Signature]
 25/9/23

ADD/OWN

Sir FT letter is put up for sign.

[Signature]
 DIRECTOR
 29/9/23

[Signature]
 25/9/23