



**FIRE SAFETY CERTIFICATE**

Certified that the YMCA Public School located at Railway Station Road, Rahim Khan Marg, Jaipur Estate, Near Post Office, Nizamuddin East, New Delhi-13, comprised of Ground + 3 upper floors was granted Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2020/SZ/444 dated 26.10.2020. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 25.09.2023 in the presence of Mr. C.P. Devis (Principal) and found that school building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building (Ground + 03 upper floors) is fit for occupancy of Group B "Educational Building" with effect from ...04.10.2023... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on....04.10.2023.....at New Delhi by

(Ajul Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, YMCA Public School located at Railway Station Road, Rahim Kham Marg, Jaipur Estate, Near Post Office, Nizamuddin East, New Delhi-13.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.



2/11

### INSPECTION REPORT

1	Name & address of the building	YMCA Public School located at Railway Station Road, Rahim Khan Marg, Jaipur Estate, Near Post Office, Nizamuddin East, New Delhi-13.				
2	Building is comprised of	Ground + 3 upper floors				
3	Type of occupancy	Education, Group-B				
4	Type of case	Renewal				
5	Details of previous FSC	F.6/DFS/MS/School/2020/SZ/444 dated 26.10.2020.				
6	Fire safety direction letter no.	UBBL/NBC-Part-IV				
7	Date of inspection	25.09.2023				
8	Name of the inspecting officers	Rajesh Kumar Shukla ADO (M. Road)				
9	Name of the designation of officer from the building side	Mr. C.P. Devis (Principal)				
10	Year of construction	2012-13 & 2017-18				
11	Applicant's letter no.	Outdoor Diary 6130 dated 15.09.2023				
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per UBBL/NBC	Provided at site	Remarks MR/NMR		
1	<b>Access to Building:</b>					
	A	Road width	6.0 mtrs.	15.0 mtrs	MR	
	B	Gate width	5 mtrs	Provided	MR	
	C	Width of internal road	NA	NA	NA	
2	<b>Number, Width, Type and Arrangement of Exits:</b>					
	A	Number of staircases				
		a	Upper floor	4 nos.	4 nos.	MR
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	1.50 m X 3 nos. 1.27 m X 1 no.	2.10 m 1.60 m, 1.53 m & 1.51 m	MR
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	2 nos.	2 nos.	MR (2014)	
	E	Width of corridor	1.50 mtrs	2.20 mtrs	MR	
	F	Door size	1.0 mtrs. (class room)	1.0 mtrs. (class room)	MR	
3	<b>Compartmentation:</b>					
	A	Fire check door	NA	NA	NA	
	B	Sealing of electrical shafts	NA	NA	NA	
	C	Fire rating of shaft door	NA	NA	NA	
	D	Water curtain	NA	NA	NA	
	E	Fire dampers	NA	NA	NA	
4	<b>Smoke Management System:</b>					
	A	Basement	NA	NA	NA	
	B	Upper floor	Natural	Natural	MR	

YMCA Public School located at Railway Station Road, Rahim Kham Marg, Jaipur Estate, Near Post Office, Nizamuddin East, New Delhi-13

w      

N/12

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	16 nos.	25 nos.	MR
	<b>B</b>	Types	CO <sub>2</sub> & ABC	Provided	MR
	<b>C</b>	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	2 nos.	2 nos,	MR
	<b>B</b>	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	<b>C</b>	Nozzle diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	NA	NA	NA
	<b>B</b>	Location of main panel	NA	NA	NA
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	NA	NA	NA
	<b>E</b>	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>		NA	Provided	NA
<b>9</b>	<b>Public Address System:</b>		NA	Provided	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
	<b>A</b>	<b>Ground level</b>			
	<b>a</b>	Discharge of main pump	NA	NA	NA
	<b>b</b>	Head of main pump	NA	NA	NA
	<b>c</b>	Number of main pumps	NA	NA	NA
	<b>d</b>	Jockey pump out put	NA	NA	NA
	<b>e</b>	Jockey pump head	NA	NA	NA
	<b>f</b>	Standby pump out put	NA	NA	NA
	<b>g</b>	Standby pump head	NA	NA	NA
	<b>h</b>	Auto starting /manual stopping	NA	NA	NA
	<b>i</b>	Pump house access	NA	NA	NA
	<b>B</b>	<b>Terrace Level</b>			
	<b>a</b>	Discharge of pump	450 LPM	450 LPM	MR
	<b>b</b>	Head of the pump	40 mtrs.	40 mtrs.	MR
	<b>c</b>	Power supply	Required	Provided	MR
	<b>d</b>	Auto starting of pump	Required	Provided	MR

YMCA Public School located at Railway Station Road, Rahim KhamnMarg, Jaipur Estate, Near Post Office, Nizamuddin East, New Delhi-13.

N/12



N/13

YMCA Public School located at Railway Station Road, Rahim Kham Marg, Jaipur Estate, Near Post Office, Nizamuddin East, New Delhi-13.

<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	NA	50,000 ltrs	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	10,000 ltrs	Provided	MR
<b>15 Exit Signage:</b>		Required	Provided	MR
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
<b>17 Standby Power Supply:</b>		Required	Provided	MR
<b>18 Refuge Area:</b>				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
<b>19 Fire Control Room:</b>				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>		NA	NA	NA

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).**

The fire safety provisions provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F.6/DFS/MS/School/2020/SZ/444 dated 26.10.2020 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

*[Handwritten Signature]*  
26/9/23.

Signature of the Inspecting Officer  
Name Rajesh Kumar Shukla  
Designation ADO (M. Road)

DO (SD)

*[Handwritten signatures and dates]*  
Mush  
26/9  
CFO  
3/10/2022  
Director  
10/10/20

*[Handwritten signature]*