



C-41

75
आजादी का
अमृत महोत्सव**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI****HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F6/DFS/MS/School/2023/NDZ/703

Dated: 04/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Fair Child Public School located at B-3/365, 33ft Road, Harsh Vihar, Delhi-110093 now comprised of **Ground & Three Upper Floors** only owned / occupied by Fair Child Public School, have earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2019/NDZ/707 Dated 03/04/19 (For Ground & Two Upper Floor only) have complied with the fire prevention and Fire safety requirements in accordance with NBC Part - IV and verified by the officer concerned of Fire Service on 15/09/2023 in presence of Sh. Pradeep Garg and that the building / premises is fit for occupancy class "**Educational**" (**Group B**) (**Ground & Three Upper Floors only**) and with effect from 04/10/2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/10/2023 at New Delhi by

(ATUL GARG)
DIRECTOR.

DELHI FIRE SERVICE

Copy to :-

1. The Manager, Fair Child Public School, B-3/365, 33ft Road, Harsh Vihar, Delhi-110093.
2. Dy. Health Officer, MCD, Shahdara North Zone, Delhi.
3. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Fair Child Public School, B-3/365, 33ft Road Harsh Vihar, Delhi-110093.
2. Building is comprised of : Ground & Three Upper Floor only
3. Type of Occupancy : Educational
4. Type of Case : New (Addition of 3rd Floor on existing G+2)
5. Details of previous NOC : F6/DFS/MS/School/2019/NDZ/707 Dated 03/ (For Ground & Two Upper Floor only)
6. Fire Safety directives Letter No.: NBC (Part-IV)
7. Date of inspection : 15/09/2023
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer from the building side : Mr. Pradeep Garg
10. Year of Construction : 2001, 2006, 2011 & 2022
11. Applicant's letter No. : DHO/Shah(N)/2023/D-542 dated 26/07/23

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at Site	R
1.	Access of building			
	• Road width	6 mtr	Provided	M
	• Gate width	4.50 mtr	Provided	M
	• Width of internal road	N/A	N/A	N/
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	4	MI
	• Basements	N/A	N/A	N/
	b. Width of staircases			
	• Upper floors	1.50 m	1.50m x 2 & 1.70m x 2	MF
	• Basements	N/A	N/A	N/
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/
	• Pressurization	N/A	N/A	N/
	d. No of continuous staircase to terrace	02 nos.	04 nos.	MR
	e. Width Of Corridor	1.5 m	2.40 m	MR
	f. Door Size	1.00 m	1.00m x 2	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	14 nos.	25 nos.	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 nos.	02 nos.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	100 mm	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR

✗

✓

N125

16.	Provision of Lifts.			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Ashok Kumar Jaiswal
18/09/2023

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Division)

Dy. C.F.O. (N32)

P. SPIC

King
19/09/23

DO (ED)

- Spoken on 27/09/23 about N/22.
- file is submitted please.

King
27/09/23

C.F.O.
29/09/2023

Director
29/9/22

D. K. Paul

P.T.O.