



No. F6/DFS/MS/WZ/2023/ 472

Dated: 05/10/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Kamal Pharmacy Ayurvedic Pvt. Ltd., located at 14 Industrial Area, Shivaji Marg, Najafgarh Road, New Delhi-110015, in a building comprised of Ground, Mezzanine & First Floor only, was issued Fire safety Certificate vide Letter No. F6/DFS/MS/WZ/2020/358 dated 11/09/2020, the premises was re-inspected by officer concerned of this department on 23/09/2023 in the presence of Sh. Vijay Grover and observed that the fire prevention and fire safety arrangements provided in the premises found in good working condition. The said building/Premises have deemed complied with the fire prevention & fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule 2010 & that the building/premises is fit for occupancy class "Industrial" Group - G (G+1) with effect from 05/10/2023 for a period of three year in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 condition mentioned below.

Issued on...05/10/2023.....at New Delhi by.

(Atul Garg)
Director

Copy to:

1. The Authorized Signatory, Kamal Pharmacy Ayurvedic Pvt. Ltd., 14, Industrial Area, Shivaji Marg, Najafgarh Road, New Delhi - 110015.

Following Fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building	Kamal Pharmacy Ayurvedic Pvt. Ltd. Located at 14. Industrial Area, Shivaji Marg, Najafgarh Road, New Delhi-110015.
2. Type of Occupancy	Class - G (G1) Industrial
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/WZ/2020/358 dated 11/09/2020
5. Fire Safety directives letter No	N.A
6. Date of inspection	23/09/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Vijay Grover
9. Year of Construction	2005-06 (As per prev. insp. dated 02/09/2020)
10. Applicant's letter No.	Outdoor diary no. 4979 dated 16/08/2023

* The said building is comprised of Ground floor, Mezzanine floor & 1st Floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	12 m Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts	A) GF to MF- 1x1.10 & 1x0.70mts B) GF to T - 1x1.30 mts	MR (Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	Halls only	Halls only	Halls only
	g. Door Size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Exhaust fans are provided	MR
5	Fire Extinguishers			
	• Total numbers	10	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

SA

*

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8	MOEFA	NR	NR	NR
9	Public Address System.	NR	NR	NR
10	Automatic Sprinkler System.			
	• Basement	NR	NR	NR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	NR	NR	NR

84

X

~24

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/WZ/2020/358 dated 11/09/2020 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

ADO/MNO
19/23

~~DYCP/WZ~~

Signature
26/9/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

~~Signature~~
26/9

1062
dated 26/9/2023

~~Signature~~
27/9/2023

~~Signature~~
27/9/2023

~~Signature~~

put-up F.T.

~~ADO(MN)~~

~~Signature~~
29/9/2023

Sir, F.T is put up for your kind personal & sig. pls