



No.F6/DFS/MS/INDL/NDZ/2023/ 475

Dated: 06/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Hira Sweets Manufacturing Private Ltd located at Plot No. 440, FIE, Patparganj Industrial Area, Delhi-110092, comprised of Basements, Ground + 01 upper floors, owned / occupied by M/s Hira Sweets Manufacturing Private Ltd. was issued Fire Safety Certificate vide letter No. F6/DFS/MS/INDL/2020/NDZ/410 dated 09.10.2020. The premises was re-inspected by the officers concerned of this department on dated 23.09.2023 in the presence of Mr. Deepak Sharma (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy Group G-1 "Industrial Building" with effect from.... 06/10/2023..... For a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued 06/10/2023 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Manager, Hira Sweets Manufacturing Private Ltd located at Plot No. 440, FIE, Patparganj Industrial Area, Delhi-110092.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 Basement shall be used strictly as per Building By-Laws 1983.
- 9 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

PINSPECTION REPORT

| | | | | | |
|-------|--|---|--------------------------------|-----------------------|------|
| 1 | Name & address of the building | Hira Sweets Manufacturing Private Ltd located at Plot No. 440, FIE, Patparganj Industrial Area, Delhi-110092. | | | |
| 2 | Building is comprised of | Basement + Ground + 01 Upper floor | | | |
| 3 | Type of occupancy | Industrial Building | | | |
| 4 | Type of case | Renewal | | | |
| 5 | Details of previous FSC | F6/DFS/MS/INDL/2020/NDZ/410 dated 09.10.2020 | | | |
| 6 | Fire safety direction letter no. | NBC Part-IV | | | |
| 7 | Date of inspection | 23.09.2023 | | | |
| 8 | Name of the inspecting officers | A.K.Jaiswal, DO (ED) & Yashwant Singh Meena ADO (L.N) | | | |
| 9 | Name of the designation of officer From the building side | Mr. Deepak Sharma (Manager) | | | |
| 10 | Year of construction | 1996 | | | |
| 11 | Applicant's letter no. | Outdoor Diary No. 6109 dated 15/09/2023 | | | |
| S. No | Minimum standard of Fire Prevention and Fire Safety U/R 33 | Requirements NBC NBC-IV | Provide at site | Remarks MR/NMR | |
| 1 | Access to Building | | | | |
| | A | Road width | 09 mtrs | 12 mtr | MR ✓ |
| | B | Gate width | N/A | N/A | N/A |
| | C | Width of internal roads | N/A | N/A | N/A |
| 2 | Number, Width, Type & Arrangement of Exits | | | | |
| | A | No. of staircase: | | | |
| | | a) Upper floor | 02 nos. | 02 nos. | MR |
| | | b) Basements | 02 nos. | 02 nos. | MR |
| | B | Width of the staircase: | | | |
| | | a) Upper floors | 1.25 mtrs. | 1.50 mtrs & 1.25 mtrs | MR ✓ |
| | | b) Basements | 1.25 mtrs. | 1.50 mtrs & 1.25 mtrs | MR ✓ |
| | C | Protection of Exits | | | |
| | | a) Fire check door | Required | Provided | MR |
| | | b) Pressurization | Required | Provided | MR |
| | D | No. of continuous staircase to terrace: | 01 no. | 02 nos. | MR ✓ |
| | E | Width of the corridor | 1.50 mtrs | 1.50 mtrs | MR ✓ |
| | F | Door size | 2.0 mtrs | 2.0 mtrs | MR ✓ |
| 3 | Compartmentation: | | | | |
| | A | Fire check doors | Required | Provided | MR |
| | B | Sealing of horizontal & vertical opening | Required | Provided | MR |
| | C | Fire rating of shaft doors | Required | Provided | MR |
| | D | Water curtain | N/A | N/A | N/A |
| | E | Fire dampers | N/A | N/A | N/A |
| 4 | Smoke management System: | | | | |
| | A | Basements | Required | Provided | MR |
| | B | Upper floors | Required | Provided | MR |
| 5 | Fire extinguishers | | | | |
| | A | Total numbers | 12 nos. | 12 nos. | MR ✓ |
| | B | Types | ISI marked ABC/CO ₂ | Provided | MR |
| | C | ISI marking | ISI marked | Provided | MR |

A

| | | | | |
|-----------|--|-------------|-------------|-----|
| 6 | First Aid Hose Reel | | | |
| A | Total no. at each floor | 01 no. | 01 no. | MR |
| B | Length of hose reel | 30 mtrs | 30 mtrs | MR |
| C | Nozzle diameter | 5 mm | 5 mm | MR |
| 7 | Automatic Fire Detection and Alarm System | | | |
| A | Type of detectors | Required | Provided | MR |
| B | Location of main Panel | Required | Provided | MR |
| C | Location of repeater panel | Required | Provided | MR |
| D | Alternate power source | Required | Provided | MR |
| E | Hooter's location | Staircase | Provided | MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System | | | |
| A | Basement | Required | Provided | MR |
| B | Upper floor | N/A | N/A | N/A |
| C | Sprinklers above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| A | Size of the riser/down comer | 100 mm | 100 mm | MR |
| B | No. of hydrants per floor | 01 no. | 01 no. | MR |
| C | Hose box | 01 no. | 01 no. | MR |
| 12 | Yard Hydrants | | | |
| A | Total no. of hydrants | N/A | N/A | N/A |
| B | Hose box | N/A | N/A | N/A |
| 13 | Pumping arrangements | | | |
| A | Ground Level | | | |
| a) | Discharge of main pump | N/A | N/A | N/A |
| b) | Head of Main Pump | N/A | N/A | N/A |
| c) | Number of Main Pump | N/A | N/A | N/A |
| d) | Jockey Pump out put | N/A | N/A | N/A |
| e) | Jockey Pump Head | N/A | N/A | N/A |
| f) | Standby Pump out put | N/A | N/A | N/A |
| g) | Standby Pump Head | N/A | N/A | N/A |
| h) | Auto Stating/ Manual | N/A | N/A | N/A |
| i) | Pump House Access | N/A | N/A | N/A |
| B | Terrace Level | | | |
| a) | Discharge of Pump | 900 LPM | 900 LPM | MR |
| b) | Head of terrace pump | 40 mtrs | 40 mtrs | MR |
| c) | Power supply | Required | Provided | MR |
| d) | Auto starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| A | Underground tank capacity | 20,000 ltrs | 20,000 ltrs | MR |
| B | Draw off connection | N/A | N/A | N/A |
| C | Fire Service Inlet | Required | Provided | MR |
| E | Access to tank | Required | Provided | MR |
| D | Overhead tank capacity | 10,000 ltrs | 10,000 ltrs | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16 | Provision of lift | | | |
| A | Pressurization of lift shaft | N/A | N/A | N/A |
| B | Pressurization of lift lobby | N/A | N/A | N/A |
| C | Communication in lift car | N/A | N/A | N/A |
| D | Fireman switch | N/A | N/A | N/A |
| E | Lift signage | N/A | N/A | N/A |
| 17 | Standby Power Supply | Required | Provided | MR |

X

sp/

| | | | | |
|----|--|-----|-----|-----|
| 18 | Refuge Area | | | |
| A | location | N/A | N/A | N/A |
| B | Total area | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| A | Fire Detection System panel | N/A | N/A | N/A |
| B | Flow switch panel | N/A | N/A | N/A |
| C | P A system panel | N/A | N/A | N/A |
| D | Battery backup | N/A | N/A | N/A |
| E | Building floor plan | N/A | N/A | N/A |
| 20 | Special Fire Protection for special risk if any | | | |
| A | Special Fire Protection system for Protection of Special Risk, if any: | NA | NA | NA |

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of above. The deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC issued vide letter no. F6/DFS/MS/INDL/2020/NDZ/410 dated 09.10.2020 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
Name: A.K. Jaiswal
Designation: DO (ED)

Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: ADO (L.N)

Dy.CFO (NDZ)

C.F.O.

Director

F. T Letter is outup for Sign. Please

Director

29.9.2023