



C48

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2023/NDZ/ 718

Dated: 10/10/2023

FIRE SAFETY CERTIFICATE

Certified that Aryan Pubic School running on ground and first floor building comprised of ground plus three upper floors located at C-212, Street no. 06, Chauhan Banger, Brahmpuri Delhi-110053, owned/occupied by Aryan Public School was issued FSC vide letter No. F.6/MS/DFS/2005/1412 dated 01/07/2005. The premises was re-inspected by the officer concerned of this department on dated 11/09/2023 in the presence of Mr. Babu Singh (Manager) and observed that all the fire Prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational Building (Group-B)' with effect from 10/10/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on10/10/2023... at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

ok l.

To:-

The Principal
Aryan Pubic School located at C-212, Street no. 06,
Chauhan Banger, Brahmpuri Delhi-110053

Copy to:-

The Dy. Director of Education
B-Block, Yamuna Vihar Vihar, New Delhi-110092

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground and first floor only. Applicant has submitted an undertaking dated 11/09/2023 that he will not use 2nd floor & 3rd floor for school purpose failing which this FSC should be treated null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

2/8

1. Name & address of the building : Aryan Public School, C-212, Main Road, Brahmpuri, Delhi-110053.
2. Building is comprised of : Ground plus three upper floors
(School is running ground plus first floor only & 2nd, 3rd floor lying vacant not used for school purpose
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/MS/DFS/2005/1412 dated 01/07/2005
6. Fire Safety directive letter No : Circular No. 262-362 dated 17/01/2005 issued by DoE.
7. Date of Inspection : 11/09/2023
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of officer from the building side : Mr. Babu Singh (Manager)
10. Year of Construction : 2004
11. Applicant's letter No : A.P.S/DDE-II/2023/115 Dated- 07/08/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	18mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 nos	02 nos	MR
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr	01 mtr & 0.75	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	N/A
	e. Width of corridor	1.50 mtr	2.40 mtr	MR
	f. Door Size	01 mtr	01 mtr	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

R. A A

N/9

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	220 Lpm	220 Lpm	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	2500 Ltr.	2500	MR
15	Exit Signage.			
		Required	Provided	MR

✓ ✗ ①

N/10

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

Note:- Building comprised of ground plus three upper floor but management has given undertaking dated 11/09/2023 at C-45 that they will not use second floor & third floor for school purpose and any purpose in any case. FSC is recommended for ground and first floor only.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter no. F.6/MS/DFS/2005/1412 dated 01/07/2005 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Deepak
15/09/2023

Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

~~DO (ED)~~
Abhishek
19.9.2023

By CFO (A.D.O.)
Divy
22/9/23

C.F.O.
Shubh
25/9/2023

Director
M
27/9/23

ADY SH