

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2023/School/WZ/ 725

Dated: 10/10/2023

FIRE SAFETY CERTIFICATE

Certified that Govt. Sarvodaya Kanya Vidyalaya, Kanjhawla, Delhi-81 comprised of Seven blocks, Ground floors only owned/occupied by that Govt. Sarvodaya Kanya Vidyalaya was issued fire safety certificate vide letter no. F.6/DFS/MS/2020/347 dated 15.09.2020. The premises was re-inspected by the officer from this department on dated 20.09.2023 in the presence of Smt. Manju Lata (Vice Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition The premises have therefore deem complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 10/10/2023 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 10/10/2023 at New Delhi by


 (Atul Garg)
 DIRECTOR
 Ph; 011-23414000

Copy to:

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya, Kanjhawla, Delhi-81
2. The Director of Education, Old Secretariat, Delhi

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>
<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

INSPECTION REPORT

Seven blocks, ground floor only

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya, Kanjhawla, Delhi-81
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2020/347 dated 15.09.2020
5. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
6. Date of inspection : 20.09.2023
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers
from the building side : Smt. Manju Lata (Vice Principal)
9. Year of Construction : 1967
10. Applicant's letter No. : Online e-mail dated 05.09.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 mtr Hall-1.5 mtr	1.0 mtr Double door 1.70 & 1.50 mtr	MR MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			


N/17


N/A
N/A
N/A

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2020/347 dated 15.09.2020. Renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended


 Signature of the Inspecting Officer
 Name :- A.K.Sharma
 Designation:- ADO/Rohini

Dy. CFO (WZ) 

P.T.O