



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7-
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2023/ 719

Dated:- 10/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarodaya Kanya Vidyalaya (Old Building) (ID-1617028) Located at Peera Garhi Village, Delhi-110087, comprised of Ground + 01 Upper Floor & A Multipurpose Hall on Ground Floor only owned/occupied by Govt. Sarvodaya Kanya Vidyalaya was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/453 Dated 29.10.2020. The said premise was re-inspected by the officer concerned of this department on 13.09.2023 in the presence of Sh. Udhvir Singh (Estate Manager) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 10/10/2023 for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on 10/10/2023.. at New Delhi by.

(Mu. Garg)
Director
Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Govt. Sarodaya Kanya Vidyalaya (Old Building) (ID-1617028), Peera Garhi Village, Delhi-110087.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

~ 14

1. Name and address of the building: **Govt. Sarvodaya Kanya Vidyalaya (Old Building) (ID-1617028) Located at Peera Garhi Village, Delhi-110087**
2. Type of Occupancy : Educational (G + 01 Upper Floor & A Multipurpose Hall on Ground Floor Separate from School building)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/453 Dated 29.10.2020
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 13.09.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Udhvir Singh (Estate Manager)
9. Year of Construction : 2008
10. Applicant's letter No. : email dated 26.08.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/ as per FSC dated 29.10.2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none">• Road width• Gate width• Width of internal road	<ul style="list-style-type: none">06 m4.5 mNA	<ul style="list-style-type: none">ProvidedProvidedNA	<ul style="list-style-type: none">MRMRNA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none">• Upper floors• Basements	<ul style="list-style-type: none">01NA	<ul style="list-style-type: none">05NA	<ul style="list-style-type: none">MRNA
	b. Width of staircases			
	<ul style="list-style-type: none">• Upper floors• Basements	<ul style="list-style-type: none">1.5 mNA	<ul style="list-style-type: none">1.5 m x 5NA	<ul style="list-style-type: none">MRNA
	c. Protection of exits			
	<ul style="list-style-type: none">• Fire check door• Pressurization	<ul style="list-style-type: none">NANA	<ul style="list-style-type: none">NANA	<ul style="list-style-type: none">NANA
	d. No of continuous staircase to terrace	<ul style="list-style-type: none">01	<ul style="list-style-type: none">Provided	<ul style="list-style-type: none">MR
	e. Width Of Corridor	<ul style="list-style-type: none">1.5 m	<ul style="list-style-type: none">Provided	<ul style="list-style-type: none">MR
	f. Door Size	<ul style="list-style-type: none">1 m & 1.5 m (M.P. Hall)	<ul style="list-style-type: none">Class Room- 1.5 mM.P. Hall- 1.5 m x 2 & 0.90 m x 2	<ul style="list-style-type: none">MR
3.	Compartmentation		NA	
	<ul style="list-style-type: none">• Fire check door• Sealing of electrical shafts• Fire Rating of shaft door• Water Curtain• Fire Dampers	<ul style="list-style-type: none">NANANANANA	<ul style="list-style-type: none">NANANANANA	<ul style="list-style-type: none">NANANANANA
4.	Smoke managements System			
	<ul style="list-style-type: none">• Basements• Upper floors	<ul style="list-style-type: none">NANA	<ul style="list-style-type: none">NANA	<ul style="list-style-type: none">NANA

5.	Fire Extinguishers			
	• Total numbers	15 nos.	26 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

10

18.	Refuge Area	NA	NA	NA
	> Total area	NA	NA	NA
	> Location			
19.	Fire control room	NA	NA	NA
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;			

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - During inspection, it was observed that Multipurpose hall was made up of concrete. Hence, fix fire fighting arrangements at stage is not required. Also there is no fix seating arrangement in this multipurpose hall and floor of multipurpose is also made up of concrete.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2020/453 Dated 29.10.2020 is recommended.

Accordingly DFA is put up for approval please.

Q11th
25/09/23
Aman Kumar Lathar
ADO (JWP)

20/10/2023
20/10/23
6/10
6/10/2023
Director
6/10/23
ADP/JWP

Sir, F.T. letter is added for your signature plz.

Director
6/10/23

Q11th
09/10/23
ADP (JWP)