



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2023/ 724

Dated:- 10/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Sarodaya Bal Vidyalaya (ID-1411001) Located at Anandwas, Lok Vihar, Delhi-110034, comprised of 03 Blocks (Ground + 01 Upper Floor) owned/occupied by Sarvodaya Bal Vidyalaya was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/WZ/2020/328 Dated 08.09.2020. The said premise was re-inspected by the officer concerned of this department on 29.09.2023 in the presence of Sh. Narender Kumar (Principal) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 10/10/2023 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 10/10/2023.... at New Delhi by.

(Atul Garg)
Director
Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Sarodaya Bal Vidyalaya (ID-1411001), Anandwas, Lok Vihar, Delhi-110034.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Sarvodaya Bal Vidyalaya** Located at **Anandwas, Lok Vihar, (ID-1411001), Delhi-110034**
2. Type of Occupancy : Educational, 03 Block (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2020/328 Dated 08.09.2020
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 29.09.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Narender Kumar (Principal)
9. Year of Construction : 1976
10. Applicant's letter No. : Form 'J' dated 19.08.2023

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/ as per FSC dated 08.09.2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	08 m	MR
	• Gate width	Accessible	05 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	BL-1 & BL-2 = 02 BL-3 = 01	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	BL-1=2 x 1.5 m (Including Railing) BL-2=1 x 1.6 m & 1 x 1.5 m (Including Railing) BL-3=1 x 1.5 m (Including Railing)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	155 cm	MR
	f. Door Size	1.0 m	115 cm	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers • Total numbers • Types • ISI marking	18 nos.	Provided	MR
		ABC & CO ₂	Provided	MR
		ISI marked	Provided	MR
6.	First - Aid Hose Reels • Total numbers on each floor • Length of hose reel hose • Nozzle diameter	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System			
10.	Automatic Sprinkler System • Basements • Upper Floor • Sprinkler above false ceiling	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants: • Size of riser/down- comer • Number of hydrants per floor • Hose Box	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants • Total number of hydrants • Hose Box	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements: • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting: • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA

De

18.	Refuge Area			
	> Total area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2020/328 Dated 08.09.2020 is recommended.

Accordingly DFA is put up for approval please.

Q1117
22/09/23
Aman Kumar Lathar
ADO (JWP)

DCP 06/23

3/10

3/10/2023

5/11/2023
3/11/2023

Director

3/11/23

ADP JWP

Sup. F.F. letter is put-up for your signature Sir.

Director

3/11/23

Q1117
05/11/23
ADO (JWP)

n