



c/16



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2023/NDZ/ 716

Dated: 09 / 10 / 2023

**FIRE SAFETY CERTIFICATE**

Certified that the Titiksha Modern Public School located at F-401, Khajoori Pusta Road, West Karawal Nagar, Delhi-110094, building comprised of **Ground plus One upper floor**, owned / occupied by Titiksha Modern Public School, was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2018/NDZ/988 Dated 10/05/2018. The School building was re-inspected by the officer concerned of this department on 29/09/2023 in presence of Sh. Harvinder Budhi Raja (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with **Circular No. 262-362 dated 17/01/2005** issued by Director of Education and that the building is fit for occupancy class "**Educational**" (Group-B) with effect from 09 / 10 / 2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 09/10/2023 at New Delhi by.

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Manager, Titiksha Modern Public School, F-401, Khajoori Pusta Road, West Karawal Nagar, Delhi-110094.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction. if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building: Titiksha Modern Public School,  
F-401, Khajoori Pusta Road,  
West Karawal Nagar, Delhi-110094.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/NDZ/988 Dt. 10/05/2018
5. Fire Safety directives Letter No.: Circular No. 262-362 Dt. 17/01/2005
6. Date of inspection : 29/09/2023
7. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
8. Name and designation of Officer from the building side : Sh. Harvinder Budhi Raja (Manager)
9. Year of Construction : 2000
10. Applicant's Letter No. : Nil Dated 21/09/2023

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E. Cir Req. 17/01/2005	Provided at Site	Remarks
1	Access to building			
	• Road width	6 m	6 m	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 nos.	03 nos.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.50 m	1.20, 1.00 m & 0.80 m	MR (old accepted)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 m	1.50 m	MR
	f. Door size	1.00 m	1.00 m	MR
3	Compartmentation			
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	04 Nos.	08 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

A

N/A			
6	First-aid-Hose Reels		
	• Total numbers of each floor	01 nos.	01 nos.
	• Length of hose reel hose	30 m	30 m
	• Nozzle diameter	05 mm	05 mm
7	Automatic fire detection and alarming system		
	• Type of detectors	N/A	N/A
	• Location of main panel	N/A	N/A
	• Location of repeater panel	N/A	N/A
	• Alternate source of power	N/A	N/A
	• Hooter's location	N/A	N/A
8	MOEFA	N/A	N/A
9	Public address System	N/A	N/A
10	Automatic Sprinkler System		
	• Basement	N/A	N/A
	• Upper Floor	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A
11	Internal Hydrants		
	• Size of rise/down-comer	N/A	N/A
	• Number of Hydrants per Floor	N/A	N/A
	• Hose Box	N/A	N/A
12	Yard Hydrants		
	• Total number of Hydrants	N/A	N/A
	• Hose Box	N/A	N/A
13	Pumping Arrangements		
	• Ground Level		
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main Pump	N/A	N/A
	➤ Number of main Pumps	N/A	N/A
	➤ Jockey pump output	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby pump output	N/A	N/A
	➤ Standby pump head	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A
	➤ Pump house access	N/A	N/A
	• Terrace Level		
	➤ Discharge of pump		
	➤ head of the pump	220 LPM	220 LPM
	➤ Power supply	40 m	40 m
	➤ Auto Starting of pump	Required	Provided
		Required	Provided
14	Captive Water Storage for Fire Fighting		
	• Underground tank capacity	N/A	N/A
	➤ Draw-off connection	N/A	N/A
	➤ Fire service inlet	N/A	N/A
	➤ Access to tank	N/A	N/A
	• overhead Tank capacity	2500 Ltrs.	2500 Ltrs.
15	Exit Signage	N/A	N/A

✱

50/

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required in Director of Education Circular No. 262-36 Dt. 17/01/2005, The Fire Safety Certificate issued vide letter no F6/DFS/MS/School/2018/NDZ/988 Dt. 10/05/2018 is recommended to be renewed.

*Ashok Kumar Jaiswal*  
29-9-22

Signature of the Inspecting Officer  
Name: Ashok Kumar Jaiswal  
Designation: D.O. (East. Div.)

~~DY. C.F.O. (NDZ)~~

~~King~~  
30/9/23

~~C.F.O.~~  
3/10/2023

~~Director~~  
A/10/23

~~Dy. Insp.~~

F.T. is added for signature please.

~~Director/MS~~  
5/10/23

~~Director~~  
5/10/23

M