

218

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/NDZ/2023/ 732

Dated: 12/10/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **D. A. V. Public Primary School** located at **Darya Ganj, New Delhi - 110002**, comprised of **Ground + 01 upper floor, Ground floor- D.A.V. Public Primary School & 1<sup>st</sup> floor- H.M.D.A.V. Senior Secondary School** was granted FSC by this department vide letter no F6/DFS/MS/School/2018/310 dated 27.02.2018. The premises was re-inspected by the officer concerned of this department on 05.10.2023 in the presence of Mr. Sachin Kumar (Accountant) and found that the building is comprised of **ground + 01 upper floor** and now the floor wise occupancy is **ground floor - D.A.V. Public Primary School & 1<sup>st</sup> floor - H. M. D. A. V. Senior Secondary School**. The building have deemed complied with the fire prevention and fire safety requirements in accordance with circular no. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03.2011 issued by Director of Education and the premises/ building is fit for occupancy of **Class-B "Educational Building"**, for **D. A. V. Public Primary School running at ground floor only** with effect from .....12/10/2023...for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on .....12/10/2023.....at New Delhi by

  
**(Atul Garg)**  
 Director  
 Delhi Fire Service  
 Tel: 011-23414000

**Copy to:-**

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal,  
D. A. V. Public Primary School at Darya Ganj, New Delhi - 110002.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



**INSPECTION REPORT**

1	Name and address of the building:	D. A. V. Public School, Darya Ganj, Delhi - 110002.
2	Type of occupancy with details of floors:	<b>Educational Building Group -B</b> (Ground + 01 upper floor) (D. A. V. School running at Ground floor only) 1 <sup>st</sup> floor- H.M. D.A.V Senior Sec. School
3	Type of case:	Renewal
4	Details of previous FSC:	F6/DFS/MS/School/2018/310 dated 27.02.2018
5	Fire safety directives no.:	NA
6	Date of inspection:	05.09.2023
7	Name of the inspecting officer:	Sumit Kumar, ADO (SPM)
8	Name and designation of the officer from the building side:	Mr. Sachin Kumar (Accountant)
9	Year of construction:	Old
10	Reference letter no.:	Outdoor diary no. 6124 dated 15.09.2023

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As per Education Circular	Provide at site	Remarks MR/NM R	
1	<b>Access to Building</b>				
	A	Road width	06 mtr.	06 mtr.	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>				
	A	<b>No. of Staircase:</b>			
		a) Upper floor	01 nos.	02 nos. ✓	MR
		b) Basements	NA	NA	NA
	B	<b>Width of the Staircase:</b>			
		a) Upper floor	1.25 mtrs.	1.25 mtr. each ✓	MR
		b) Basements	NA	NA	NA
	C	<b>Protection of Exits</b>			
		a) Fire check door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace:	NA	NA	NA
	F	Width of the corridor	NA	NA	NA
	E	Door size	1.0 mtr.	1.0 mtr. ✓	MR
3	<b>Compartmentation:</b>				
	A	Fire check doors	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	<b>Smoke management System:</b>				
	A	Basements	30 ACPH	NA	NA
	B	Upper floors	12 ACPH	NA	NA
5	<b>Fire extinguishers</b>				
	A	Total numbers	12 nos.	12 nos.	MR
	B	Types	Co2 & ABC	Provided	MR
	C	ISI marking	Required	Provided	MR



<b>6</b>	<b>First Aid Hose reel</b>			
<b>A</b>	Total no. at each floor	NA	NA	NA
<b>B</b>	Length of Hose Reel	NA	NA	NA
<b>C</b>	Nozzle diameter	NA	NA	NA
<b>7</b>	<b>Automatic Fire Detection and Alarm System (ADAS)</b>			
<b>A</b>	Type of Detectors	NA	NA	NA
<b>B</b>	Location of main Panel	NA	NA	NA
<b>C</b>	Location of Repeater Panel	NA	NA	NA
<b>D</b>	Alternate power Source	NA	NA	NA
<b>E</b>	Hooter's location	NA	NA	NA
<b>8</b>	<b>MOEFA</b>			
<b>9</b>	<b>Public Address System</b>			
<b>10</b>	<b>Automatic Sprinkler System</b>			
<b>A</b>	Basement	NA	NA	NA
<b>B</b>	Upper Floor	NA	NA	NA
<b>C</b>	Sprinklers above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal hydrants</b>			
<b>A</b>	Size of the riser/down comer	NA	NA	NA
<b>B</b>	No. Of hydrants per floor	NA	NA	NA
<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants</b>			
<b>A</b>	Total no. of hydrants	NA	NA	NA
<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping arrangements</b>			
<b>A</b>	<b>Ground Level</b>			
	a) Discharge of main pump	NA	NA	NA
	b) Head of main pump	NA	NA	NA
	c) Number of main pump	NA	NA	NA
	d) Discharge of jockey pump	NA	NA	NA
	e) Head of jockey pump	NA	NA	NA
	f) Discharge of Standby pump	NA	NA	NA
	g) Head of Standby pump	NA	NA	NA
	h) Auto starting/ manual stopping	NA	NA	NA
<b>B</b>	<b>Terrace Level</b>			
	a) Discharge of terrace pump	NA	NA	NA
	b) Head of terrace pump	NA	NA	NA
	c) Alternate power supply	NA	NA	NA
	d) Auto starting of pump	NA	NA	NA
<b>14</b>	<b>Captive Water Storage for Fire Fighting</b>			
<b>A</b>	Underground tank capacity	NA	NA	NA
<b>B</b>	Draw off connection	NA	NA	NA
<b>C</b>	Fire Service Inlet	NA	NA	NA
<b>E</b>	Access to tank	NA	NA	NA
<b>D</b>	Overhead tank capacity	NA	NA	NA
<b>15</b>	<b>Exit Signage</b>			
<b>16</b>	<b>Provision of lift</b>			
<b>A</b>	Pressurization of lift shaft	NA	NA	NA
<b>B</b>	Pressurization of lift lobby	NA	NA	NA
<b>C</b>	Communication in lift car	NA	NA	NA
<b>D</b>	Fireman switch	NA	NA	NA
<b>E</b>	Lift signage	NA	NA	NA
<b>17</b>	<b>Standby Power Supply</b>			
		NA	NA	NA

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any:			NA

The Fire Protection System provided in the school were tested, checked and random and found functional at the time of inspection.

Shortcoming communicated vide letter no. F6/DFS/MS/School/NDZ/2023/72 dated 09.02.2023 has been rectified.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under Directorate of Education, Circular FSC issued vide letter no. F6/DFS/MS/School/2018/310 dated 27.02.2018, renewal for D.A.V. Public Primary School at ground floor only, under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

*Sumit Kumar*  
6/5/10/2023

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

~~DQ(CD)~~  
~~6/2/23~~

~~Dy. CFS (NDZ)~~

~~10/9/23~~

~~C.F.O.~~  
~~10/10/2022~~

~~Director~~  
~~10/1/23~~

~~ADO/SPM~~

F.T. letter is put up for signature please.

~~Director (DFS)~~  
~~11/10/23~~

*Sumit Kumar*  
11/10/2023