

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

No. F.6/DFS/MS/2023/SZ/ EH/305  
NEW DELHI-110001

Dated. 12/10/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Little Munchkins LLT located at First Floor, Plot No 81, Adhchini, Sri Aurobindo Marg, New Delhi 110017 in the building comprised of Basement ground plus 02 upper floors owned/occupied by M/s Little Munchkins LLT have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 03/10/2023 in the presence of Mr. Kalim Admed and that the premises is fit for occupancy class "Group-D Assembly Building" with effect from 12/10/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/10/2023 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police (Lic/Branch) 1<sup>st</sup> floor, P S Defence Colony Delhi 110049 (Ref. Joint CP letters no 626-31Joint. C.P/Lic. (Amst). dated 04/08/2023)

**Conditions for the validity of Fire Safety Certificate: -**

1. **This FSC is valid for First floor of the building only.**
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."



N/A

INSPECTION REPORT				
1	Name & Address of the Building	M/s Little Munchkins LLT at Plot No 81, First Floor, Adhchini, Sri Aurobindo Marg, New Delhi 110017.		
2	Type of Occupancy	Assembly Building (Video Game Parlour First Floor only)		
3	Building Comprised of	Basement, Ground plus Two upper floors		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	03/10/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Kalim Admed		
10	Year of construction	2022		
11	Applicant letter No.	626-31Joint. C.P/Lic. (Amst). dated 04/08/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	9m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	NA	N/A	N/A
2	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	• Upper floors	02 Nos	04 Provided	MR
	• Basement floor	N/A	N/A	N/A
	<b>b. Width of Staircase</b>			
	• Upper floors	1.50 mtr	2 x 1.50 mtr, 1.25 mtr & 1.0 mtr	MR
	• Basement floor	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	Provided	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1.50 mtr	1.50 mtr	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	<b>Smoke Management system.</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors	12 APCH	Exhaust fans provided	MR
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	06 Nos	06 Nos.	MR
	• Types	ISI marked	ABC-04, W.CO <sub>2</sub> -02	MR
	• ISI Marking		Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	Hose Reel	01 at first floor	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR
7	<b>Automatic Fire Detection and Alarming system.</b>			





N/A

<ul style="list-style-type: none"> <li>• Flow Switch Panel.</li> <li>• PA system Panel.</li> <li>• Battery backup</li> <li>• Building floor plan</li> </ul>	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
	N/A	N/A	N/A	
20.	<b>Special Fire Protection System for the Protection of special Risk, if any :</b>	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

*Handwritten signature*

Signature of the Inspection Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)

*Handwritten signature*

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

CFO (HQ)

*Handwritten signature*  
6/10/2023

*Handwritten signature*  
Director  
2/10/2023

*Handwritten signature*  
ADP

As approved, F.S. letter is put up for  
your signature

*Handwritten signature*  
Director

*Handwritten signature*  
1/11/2023

N/A