

No: F.6/DFS/MS/School/WZ/2023/ 740

Dated: 16/10/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Nigam Prathibha Vidyalaya, Located at H.I. Block, Karampura, New Delhi-110015 (School ID 1556146), is comprised of Ground + One upper floor, was issued by this department vide letter No. F6/DFS/MS/School/WZ/2017/815 dated 07/06/2017. The premises was re - inspected by the officer concerned by this department on 29/09/2023 in the presence of Smt. Sonia Arya (Incharge) and found that the all the fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance DOE 3298-3398 dated 01/03/2011 and that the premises is fit for occupancy class "Education" Group B with effect from ...16/10/2023....for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010. Condition mentioned below.

Issued on ...16/10/2023... at New Delhi.

(Atul Garg)  
Director

Copy to: -

1. The Principal, Nigam Prathibha Vidyalaya, Located at H.I. Block, Karampura, New Delhi-110015 (School ID 1556146)
2. Director of Education, Old Secretariat, New Delhi-110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



N/11

## INSPECTION REPORT

1. Name & address of the building	Nigam Prathibha Vidyalaya, H.I. Block, Karampura, New Delhi-110015.(School ID: 1556146)
2. Type of Occupancy	Educational (Ground + 1)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/SCHOOL/WZ/2017/815 dated 07/06/2017
5. Fire Safety directives letter No	DOE Circular NO -3298-3398 dated 01/03/2011
6. Date of inspection	29/09/2023
7. Name of the Inspecting Officers	Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side	Smt. Sonia Arya (Incharge)
9. Year of Construction	2001 (As per pre. Insp. report dated - 26/05/2017)
10. Applicant's letter No.	Email dated: 10/08/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 Mtr	Provided	MR
	• Gate width	4.5 Mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	03 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	1X 1.37m, 1X1.46m, 1X 1.57m Provided	MR (Using old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	2.30m Provided	MR
	g. Door Size	1 m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	08 Nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

✍️ ✍️



Sl. No.	Ref.	1	2	3	
7		<b>Automatic fire detection and alarming system.</b>			
		Type of detectors	NA	NA	NA
		Location of Main Panel	NA	NA	NA
		Location of Repeater Panel	NA	NA	NA
		Alternate source of power	NA	NA	NA
		Hooters' Location	NA	NA	NA
8		<b>MOEFA</b>			
			NA	NA	NA
9		<b>Public Address System.</b>			
			NA	NA	NA
10		<b>Automatic Sprinkler System.</b>			
		Basement	NA	NA	NA
		Upper Floor	NA	NA	NA
		Sprinkler above false ceiling	NA	NA	NA
11		<b>Internal Hydrants</b>			
		Size of riser/down-comer	NA	NA	NA
		Number of hydrants per floor	NA	NA	NA
		Hose Box	NA	NA	NA
12		<b>Yard Hydrants.</b>			
		Total number of hydrants	NA	NA	NA
		Hose Box	NA	NA	NA
13		<b>Pumping Arrangements.</b>			
		Ground Level			
		➤ Discharge of main Pump	NA	NA	NA
		➤ Head of Main pump	NA	NA	NA
		➤ Number of main pumps	NA	NA	NA
		➤ Jockey Pump out put	NA	NA	NA
		➤ Jockey pump head	NA	NA	NA
		➤ Standby Pump out put	NA	NA	NA
		➤ Standby Pump Head	NA	NA	NA
		➤ Auto Starting/ Manual stopping	NA	NA	NA
		➤ Pump House Access	NA	NA	NA
		Terrace level		NA	
		➤ Discharge of pump	NA	NA	NA
		➤ Head of the pump	NA	NA	NA
		➤ Power Supply	NA	NA	NA
		➤ Auto Starting of pump	NA	NA	NA
14		<b>Captive Water Storage for fire fighting.</b>			
		Underground tank capacity	NA	NA	NA
		➤ Draw-off connection	NA	NA	NA
		➤ Fire service inlet	NA	NA	NA
		➤ Access to tank	NA	NA	NA
		Overhead Tank capacity	NA	NA	NA
15		<b>Exit Signage.</b>			
			NA	NA	NA
16		<b>Provision of Lifts.</b>			
		Pressurization of Lift Shaft	NA	NA	NA
		Pressurization of Lift lobby	NA	NA	NA
		Communication In lift Car	NA	NA	NA
		Fireman's Grounding Switch	NA	NA	NA
		Lift Signage	NA	NA	NA

7	Standby power supply	NA	NA	NA
18	Refuge Area.			
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC/FSC issued vide letter no. F6/DFS/MS/SCHOOL/WZ/2017/815 dated 07/06/2017 renewal under 35 of the Delhi Fire Service Rules 2010 is recommended.

70/ADO/MN  
03/10/2023

~~24CF/WZ~~

~~8/6/10~~

~~03/10/2023~~

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADOMN)

JCFOI... 19  
Dated... 6/10/2023

~~CFD~~  
~~6/10/2023~~  
~~Detector~~  
~~11/10/2023~~  
~~ADOMN~~

Sir, F. T is put up for your kind perusal & signature please.

~~Director~~  
~~13/10/2023~~

~~13/10/2023~~

m