

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6/DFS/MS/2023/School/WZ/ 731

Dated: 12/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidhyalaya located at Q-Block, Mangolpuri, Delhi-83, (School ID-1412080) comprised of 04 Blocks, Ground + 01 upper floor owned/occupied by Sarvodaya Kanya Vidhyalaya was granted FSC by this department vide letter No. F.6/DFS/MS/School/2021/WZ/47 dated 15.01.2021. The premises was re-inspected by the officer concerned of this department on 04.10.2023 in the presence of Smt. Anamika (Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from12/10/2023 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on12/10/2023..... at New Delhi


(Atul Garg)
DIRECTOR

Ph; 011-23414000

5/11/23
Jag

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Sarvodaya Kanya Vidhyalaya located at Q-Block, Mangolpuri, Delhi-83. (School ID-1412080).

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

20/11/24

INSPECTION REPORT				
1. Name & address of the building	Sarvodaya Kanya Vidhyalaya located at Q-Block, Mangolpuri, Delhi-83. (School ID-1412080)			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (04 Blocks, Ground + 01 upper floor)			
4. Details of Previous NOC	F.6/DFS/MS/School/2021/WZ/47 dated 15.01.2021.			
5. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.			
6. Date of inspection	04.10.2023			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Smt. Anamika (Principal)			
9. Year of Construction	1976 & 2007.			
10. Applicant's letter No.	OD No.6021 dated 13.09.2023			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Cir. Dated 01.03.11	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	Block-I-02 Block-II-02 New Block-III-02 New Block-IV-02	Block-I-01(Old case) Block-II-02(Old case) New Block-III-02 New Block-IV-03 & 1ramp	MR
	• Basements			
	e. Width of staircases			
	• Upper Floor	Block-I-1.5m Block-II-1.5m New Block-III-1.5m New Block-IV-1.5m	Block-I-1.5m(Old case) Block-II-1.5m each New Block-III-1.5m New Block-IV-1.5m	MR
	• Basements			
	f. Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m'	1.0m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	35nos.	42nos.	MR
	• Types	ABC/CO2	ABC-42 nos.	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			

[Handwritten signature]

[Handwritten signature]

4/25

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

af

af

	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. F.6/DFS/MS/School/2021/WZ/47 dated 15.01.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

Dy. CFC(WZ)
 01.170-N/26
 06/10/23

[Signature]
 6/10/2023

[Signature]
 8/10/2023

Director *[Signature]*
 11/10/23

[Signature]
 Ajay Kumar

As letter to put up for kind perusal and signature plan

Director *[Signature]*
 11/10/23

[Signature]
 11/10/23