



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/BNQT/WZ/2023/ 222

Dated: 17/10/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Pushp Aleela Banquet (A Unit of Pushpa Food and Beverages), located at A-4, Wazirpur Industrial Area, New, Delhi-110052, running at Ground + two Upper Floors, in a building comprised of 02 Basement + Ground + 02 Upper floors, Owned/Occupied by M/s. Pushp Aleela Banquet (A Unit of Pushpa Food and Beverages), was issued FSC by this department Vide letter no. F.6/DFS/MS/BNQT/2018/2742 dated 24/12/2018. The premises was re-inspected by the officer concerned of this department on 09/10/2023 in the presence of Sh. Om Prakash Asrani and found that the said premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) (For Ground + two Upper Floors only) and validity upto 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on 17/10/2023 at New Delhi by.

(Atul Gang)
Director

Copy to: -

1. The owner/occupier, M/s. Pushp Aleela Banquet (A Unit of Pushpa Food and Beverages), located at A-4, Wazirpur Industrial Area, New, Delhi-110052.
Online Application ID No. 2023092116213 dated 23/09/2023
2. The Dy. Health Officer, A-1 Block, Keshav Puram Zone, Public Health Department, New Delhi.
3. The Commissioner, MCD, Civic Centre, Minto Road, New Delhi.

INSPECTION REPORT

2-36

1. Name & address of the building	M/s. Pushp Aleela Banquet (A Unit of Pushpa Food and Beverages), Located at A-4, Wazirpur Industrial Area, New Delhi - 110052.
2. Type of Occupancy	Assembly
3. Type of Case	Renewal
4. Details of previous NOC	F.6/DFS/MS/BNQT/2018/2742 dated 24/12/2018
5. Fire Safety directives letter No	F.6/DFS/MS/2018/3574 dated 20/08/2018
6. Date of inspection	09/10/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Om Prakash Asrani
9. Year of Construction	2010-11 (As per prev. insp. report dated 19/11/2018)
10. Applicant's letter No.	Online Application ID No. 2023092116213 dated 23/09/2023

*** The said banquet hall running at Ground Floor, First Floor & Second Floor in a building Comprised of 02 Basement + Ground + 02 Upper Floors.**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 m	Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	NA	On Road	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	2 x 2 m	2 x 2m	MR
	• Basements	2 x 2 m	2 x 2m & 5.75m Ramp	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	2m	Provided	MR
	g. Door Size	2 x 2 m	GF= 1 x 1.39m, 1 x 2.14m & 2 x 2.45m FF= 1 x 1.25m, 2 x 2m & 1 x 1.42m SF= 1 x 1.83m, 1 x 2m & 1 x 2.03m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	Separate AC units are provided for individual floor	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NR	Provided	NR
	• Hose Box	NR	Provided	NR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280lpm	Provided	MR
	➤ Head of Main pump	70m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	70m	Provided	MR
	➤ Standby Pump out put	2280lpm	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NR	NR	NR
	➤ Head of the pump	NR	NR	NR
	➤ Power Supply	NR	NR	NR
	➤ Auto Starting of pump	NR	NR	NR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,00,000ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts. (Pressurization of lift lobby & lift shaft is not required as the building is low-rise & the lift will run from GF to UFs) N-38			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Manual operated Co2 & D.C.P fire extinguisher		Provided MR

The fire fighting arrangements provided in the building/banquet were checked & found functional at the time of inspection.

Note: - The Management has submitted the undertaking that the premises will not be use for any purpose except banquet. Photos for banquet use is placed opposite in the file .

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F.6/DFS/MS/BNQT/2018/2742 dated 24/12/2018 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~Dy CPO (w/z)~~

~~Signature~~
12/10/2023

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

Sl. No. 39
Jated. 12/10/2023

~~Signature~~
13/10/2023

~~Signature~~
16/10/2023
Director
~~Signature~~
16/10/2023

~~Signature~~

Uploaded
18/10/23