

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2023/EH/302

Dated: 06/10/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Xero Degrees restaurant (A unit of ID Enterprises) located at 22-B, first floor left side, Old Rajinder Nagar, New Delhi 110060, in a building comprised of Basement, stilt + Ground + 03 Upper Floors owned/ occupied By M/s. Xero Degrees restaurant have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 25/09/2023 in the presence of Mr. Manish (Cashier) and found that the said building that the premises is fit for occupancy class "Assembly" Group D(1st Floor) with effect from 06/10/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06/10/2023. at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service
25/9/23

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Manager, M/s. Xero Degrees restaurant (A unit of ID Enterprises) located at 22-B, first floor left side, Old Rajinder Nagar, New Delhi 110060.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rule's 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Xero Degrees restaurant (A unit of ID Enterprises) located at 22-B, first floor left side, Old Rajinder Nagar, New Delhi 110060.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives L. No. : NBC/UBBL
6. Date of inspection : 25/09/2023
7. Name of the Inspecting Officer ; DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Manish (Cashier)
9. Year of Construction : 2010
10. Applicant's Letter No : 2023091816109, dated-19/09/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01 Nos.	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2X1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided in kitchen	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural Vent	MR

Handwritten signature

~113

16.	Provision of Lifts Common with the building			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel.	MR

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

1. M/s. Xero Degrees restaurant (A unit of ID Enterprises) located at 22-B, first floor left side, Old Rajinder Nagar, New Delhi 110060.
2. The total covered area for restaurant = 199 M²
3. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 111 (199/1.8=110.5) for whole restaurant.
4. The total seating capacity comes out to be 111.

Signature of the Inspecting Officer
 Name: Sh. Vedpal
 Designation: DO/SW

Signature of the Inspecting Officer
 Name: Udai Vir Singh
 Designation: ADO/DWK

CFO/(S2)
 27/9/2023

Director

DO/SW
 29/9/23

ADO/Dwarka