

c 31

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/SZ/2023/750

Dated:- 18/10/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Army Public School located at Sadar Bazar, Delhi Cantt, Delhi - 110010 comprised of Ground + 02 upper floors owned/occupied Army Public School, was granted FSC by this department vide letter No. F6/DFS/MS/School/2019/SZ/2377 dated 27/12/2019. The premises was re-inspected by the officers concerned of this department on 04/10/2023 in the presence of the Major Payal (Admin.) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from ~~18/10~~ 18/10/2023 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 18/10/23 at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service

To,

1. The Principal,  
Army Public School,  
Sadar Bazar, Delhi Cantt, Delhi - 110010.
2. The Director of Education,  
Govt. of NCT, of Delhi, Old Secretariat, Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

12/13  
**INSPECTION REPORT**

1. Name & address of the building:- **Army Public School at Sadar Bazar, Delhi Cantt, Delhi – 110010**
2. Type of occupancy:- **Educational Building  
Gr.+ 02 upper floors**
3. Type of case:- **Renewal**
4. Details of previous FSC:- **F6/DFS/MS/School/2019/SZ/2377 dated 27/12/2019**
5. Fire safety directives No.- **N/A**
6. Date of inspection:- **04/10/2023**
7. Name of the inspecting officer:- **Sh. Manoj Kumar Sharma (DO/SD)**
8. Name & designation of officer  
From the building side:- **Major Payal (Admin.)**
9. Year of construction:- **Not know**
10. Applicant's letter No:- **19304/APSDC/FDRC/EO dated 29/06/2023**

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	DOE Circular	Provided at site	Remarks MR/NMR
1.	<b>Access to Building</b>			
	1) Road width	9 mtr.	9 mtr.	MR
	2) Gate width	4.5 m	5 mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	05 nos. + 01 ramps	05 nos. + 01 ramps	MR
	2. Basements	NA	NA	NA
	<b>B. Width of staircase</b>			
	1. Upper floors	1.5 mtr each	1.6 m (each) & ramp-1.5 m	MR
	2. Basements	NA	NA	NA
	<b>C. Protection of exits</b>			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	01 nos.	01 nos.	MR
	E. Width of corridor	NA	NA	NA
	F. Door size	1 mtr.	1 mtr.	MR
3.	<b>Compartmentation</b>			
	1) Fire check door	NA	NA	NA
	2) Sealing of electrical shafts	NA	NA	NA
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	1) Basements	NA	NA	NA
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	1) Total numbers	40 Nos.	40 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR
6.	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	05 nos.	05 nos.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR

N/119

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	NA	NA	NA
	2) Location of main panel	NA	NA	NA
	3) Location of repeater panel	NA	NA	NA
	4) Alternate source of power	NA	NA	NA
	5) Hooter's Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	
10.	Automatic Sprinkler System			
	1) Basement	NA	NA	NA
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	NA	NA	NA
	2) Number of hydrants per floor	NA	NA	NA
	3) Hose box	NA	NA	NA
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPMx2	MR
	b) Head of pump	40 m	40 m	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 liter	15,000 liter	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2019/SZ/2377 dated 27/12/2019 renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

*M.K. Sharma*  
 Signature of the Inspecting Officer  
 Name :- M.K. Sharma  
 Designation :- DO (SD)

CFO/HQ  
~~*M.K. Sharma*~~  
 12/10/2023  
~~*M.K. Sharma*~~  
 Director  
~~*M.K. Sharma*~~  
 17/11/22  
 DO/SD  
*M.K. Sharma*  
 16/12

F.T. letter is put up for sig. pl  
~~*M.K. Sharma*~~  
 Dir. DFS  
 17/11/22  
 2  
*M.K. Sharma*  
 16/12