

C 28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2023/School/WZ/ 746

Dated: 18/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Bal Sthali Public School, Kirari Suleman Nagar, Delhi-86, comprised of Ground + 01 upper floor owned/occupied by Bal Sthali Public School was granted FSC by this department vide letter No. F.6/DFS/MS/School/WZ/2020/270 dated 10.08.2020. The premises was re-inspected by the officer concerned of this department on 04.10.2023 in the presence of Sh. Devender Singh Mathur (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy Group B Educational with effect from18/10/2023.. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on18/10/2023..... at New Delhi


(Atul Garg)
DIRECTOR
Ph; 011-23414000


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Bal Sthali Public School, Kirari Suleman Nagar, Delhi - 86.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

[http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Ru
les/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/) http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

		INSPECTION REPORT		
1. Name & address of the building	Bal Sthali Public School, Kirari Suleman Nagar, Delhi – 86			
2. Type of Occupancy	Educational (School ID-1412141)			
3. Type of Case	Renewal (Ground + 01 upper floor)			
4. Details of Previous NOC	F.6/DFS/MS/School/WZ/2020/270 dated 10.08.2020			
5. Fire Safety directives letter No	Director of Education Circular 262-362 dated 17.01.2005.			
6. Date of inspection	04.10.2023			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Sh. Devender Singh Mathur (Manager)			
9. Year of Construction	2002			
10. Applicant's letter No.	OD No.5067 dated 18.08.2023.			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. dated 17.05.05 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	e. Width of staircases			
	• Upper Floor	1.5m	2 x 1.40m	MR(Old case)
	• Basements	NA	NA	NA
	f. Protection of exits			
	Fire check door			
	• Pressurization	NA	NA	NA
	• NA	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	06nos.	06nos.	MR
	• Types	ABC/CO2	ABC-06nos.	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		180lpm	180lpm	MR
		40m	40m	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		440lpm	440lpm	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5000ltr	5000ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

my

✓

N/18

	• Battery backup	NA	NA	NA
	• Building Floor Plans			
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2020/270 dated 10.08.2020 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Handwritten Signature]
11/10/23

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Dy.CFO(WZ)
[Handwritten Signature]

[Handwritten Signature]
13/10

[Handwritten Signature]
1-3/10/23

[Handwritten Signature]
13/10/2023

[Handwritten Signature]
13/10/23
ADO/Rohini

FT letter is put up for kind perusal and signature please.
[Handwritten Signature]

[Handwritten Signature]
14/10/23
Director
N