



FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/2023/ 499

Dated: 18/10/2023

FIRE SAFETY CERTIFICATE

Certified that the building of **Employees Provident Fund Organization, office building** Located at **Plot 23, Sector - 23, Dwarka, New Delhi - 110075**, owned/occupied by National Registry and Processing Centre, **Employees Provident Fund Organization (Ministry of Labour & Employees Govt. of India)** comprised of Basement + Ground + 02 Upper Floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS /2020/SZ/295, dated 05/08/2020. The premise was re inspected by the officers concerned of this department on 12/10/2023 in the presence of Sh. Sandeep Aggarwal & Sh. Sachin Gupta (From EPFO) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy Group E "Business Building" with effect from 18/10/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/10/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
18/10/23

Copy to:

1. The President, Employees Provident Fund Organization, office building, Plot 23, Sector - 23, Dwarka, New Delhi - 110075.
2. The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Employees Provident Fund Organization, office building Located at Plot 23, Sector – 23, Dwarka, New Delhi – 110077 .
2. Type of Occupancy : Business Building (Basement + Ground+ 2 U.Fs) *Group - E*
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS /2020/SZ/295, dated 05/08/2020
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2003/2711, dated-04/11/2003
6. Date of inspection : 12/10/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sachin Gupta, Sh. Sandeep Aggarwal
9. Year of Construction : 2003
10. Applicant's L.No. :RO/DLS/ADM-II/Fire Fighting system/2023-24/78, dated 04/10/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/16, N/17 & N/18	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	Provided	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	06 provided	MR
	• Basements	2 Nos. & 2 ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m each	Provided	MR
	• Basements	1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	4 Nos.	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 m & 1.5 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	2 Hrs.	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 a/c charge	Provided	MR
	• Upper floors	12 a/c charge	Provided	MR

~121

5.	Fire Extinguishers			
	• Total numbers	18 nos. each floor	Provided	MR
	• Types	ABC & CO ₂	CO ₂ , ABC, DCP	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	06 Nos.	Provided	MR
		30 m	Provided	MR
	• Length of hose reel hose	05 mm	Provided	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Ground floor near staircase	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Battery Backup	Provided	MR
	• Hooters' Location	Appropriate places	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	06 Nos. each floor	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	26 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements:			
	• Ground Level	2850 lpm	Provided	MR
	• Discharge of main pump	70 mtr	Provided	MR
	➤ Head of main pump	01	Provided	MR
	➤ Number of main pumps	180 lpm	Provided	MR
	➤ Jockey pump out put	40 mtr	Provided	MR
	➤ Jockey pump head	2850 lpm & 1620 lpm	Provided	MR
	➤ Standby Pump out put	70 mtr	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access			
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	2,00,000 ltr	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR

16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17	Standby power supply	Required	1010 & 320 KVA	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS /2020/SZ/295, dated 05/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

~~Signature of the Inspecting Officer~~
 Name: Udai Vir Singh
 Designation: ADO/DWK

~~10~~
 13/10/23
 16/10/23
 CFO(S2)
 16/10/2022
 Director
 16/10/22

AD/DWK