



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

75
आजादी का
अमृत महोत्सव

c/38

No F 6 / DFS / MS / 2023/WZ/500

Dated: 23/10/2023

FIRE SAFETY CERTIFICATE

Certified that the **National Farm** located at **Palla Bakhtawarpur Road, Alipur, Delhi-110036** comprised of Ground & First Floor owned/occupied by **National Farm** was issued Fire Safety Certificate vide letter no. **F6/DFS/MS/2020/432** dated **23/10/2020**. The premise was re-inspected by the officer concerned of this department on **29/09/2023** in the presence of **Sh. Ashish Gupta** and found that the said farm house building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building premise is fit for occupancy under "**Mixed (Assembly & Residential)**" with effect from **23/10/2023**... for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **23/10/2023** at New Delhi by

(Ajay Garg)

Director

Ph. 011-23414000

OR

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Copy to:-

1. The Assistant Engineer (Bldg.), Delhi Municipal Corporation, Narela Zone, Delhi.
2. M/s National Farm located at Palla Bakhtawarpur Road, Alipur, Delhi-110036.

INSPECTION REPORT

1. Name & address of the building : National Farm located at Palla Bakhtawarpur Road, Alipur Delhi-110036.
2. Type of Occupancy : Assembly & Residential (mix) - *As*
3. Building Comprised : Ground & First Floor.
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2020/432 dated 23/10/2020
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 29.09.2023
8. Name of Inspecting Officer : ADO R.K. Sinha
9. Name and designation of officers
From the building side : Sh. Ashish Gupta
10. Year of Construction : 2013 as per N-4
11. Applicant's letter No. : Form J via outdoor diary no. 6209 Dated 18.09.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	9 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR (old case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.25 m	1.10 m	MR(old case)
	• Basements			
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers			
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	1@300 SQM	Provided	MR
	• Types	ABC & Co2	Provided	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power 	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		01	01	MR
		01	01	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	02	Provided	MR
		Required	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump house Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided, 125 KVA	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA

29

Control Room			
<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA

The fire protection system provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2020/432 dated 23/10/2020 under rule 35 of the Delhi Fire Service Rules 2010.

(Signature)
 ADO(BW)
 3/10/23

Signature of the Inspecting officer
 Name : Rajeev Kumar Sinha
 Designation : ADO/BW

Dy CFO (1/2)

dy
 9/10

CFO Clarify the occupancy of each floor

dy
 9/10/2023

Dy CFO (1/2)

dy
 11/10

Ado (Rawana)

Sr. The ground floor has one drawing room and two bed rooms. first floor has one bed room

(Signature)
 ADO(BW)
 13/11/23

Dy CFO (1/2)

dy
 16/10

Answer: CFO Thank you Sir

CFO/...../20
 Dated... 5/10/2022

CFO/...../20
 Dated... 16/10/2023