

e 46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/751

Dated: 23/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Shaheed Captain Anuj Nayyar Sarvodaya Bal Vidyalaya No.-2, B-Block Janak Puri, New Delhi-110058, comprised of two blocks namely Old Block & New Block with one Multipurpose Hall. The Old block is having ground floor plus two upper floors having total 47 rooms (including class rooms, Library, office & store etc.) and the New block is having ground floor plus one upper floor, having total 20 rooms (including class rooms, office & store etc.) owned/occupied by Govt. of NCT of Delhi was issued Fire Safety Certificate by this department vide letter no. F F.6/DFS/MS/School/2020/SZ/484 dated 09/11/2020. The School building was re-inspected by the officer concerned of this department on 12/10/2023 in the presence of Sh. Sh. Inder Kumar (Principal) and found that school building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (Except MP Hall) is fit for occupancy class "Educational" for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.... 23/10/2023..... at New Delhi.

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  


Copy to:-

1. The Principal, S C A N Sarvodaya Bal Vidyalaya No.-2, B-Block Janak Puri, New Delhi-110058.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. In case of usage of MP Hall then Separate FSC will be required for MP Hall.

**INSPECTION REPORT**

1. Name & address of the building : Shaheed Captain Anuj Nayyar Sarvodaya Bal Vidyalaya No.-2, B-Block Janak Puri, New Delhi-110058.
2. Building comprised of : Two blocks Old blk having ground plus two upper floors & New blk having ground plus one upper floor with MP Hall (under renovation).
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/484 dated 09/11/2020
6. Fire Safety directives letter No : N/A
7. Date of inspection : 12/10/2023
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers From the building side : Sh. Inder Kumar (Principal)
10. Year of Construction : 1980-81 (Old Block) & 2012-13 (New Block)
11. Applicant's letter No. : SCAN/2023/452 dated 05/10/2023 & Form "J" & "K"

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>	Accessible 06 m	09 m	M/R
	• Road width	4.5 m	Provided	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road			
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02 No.'s in each block	02 No.'s in O-blk 03 no.'s in N-blk	M/R
	• Upper Floors	N/A	N/A	N/A
	• Basements			
	b. Width of staircases			
	• Upper Floor	1.50 & .75 m	1.28 & 1.28 m in O blk & 2.0, 1.52 & 1.55 m in N blk	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
	e. Width of Corridor	1.50 m	1.75 m in O blk & 2.35 m in N blk	M/R
	f. Door Size	1.0 m in CR & 1.50 m MP Hall	.90 m 02 no.'s in OB & 1.12 m (02 no.'s) in NB & 1.50m including frames in MP Hall	M/R, being old case
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	<b>Fire Extinguishers</b>			
	• Total numbers	20 no's	Provided	MR
	• Types	ABC/CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor for old block	02 no.'s in OB	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7.	<b>Automatic fire detection and alarming system</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access -</li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		450 LPM	Provided	MR
		30 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Underground tank capacity                             <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	Provided	N/A
		N/A	N/A	N/A
		10000 ltrs	12,000 ltrs provided	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>			No Lift
16.	<b>Provision of Lifts.</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A

15

Fire Control Room				
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/School/2020/SZ/484 dated 09/11/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:-Earlier the fire safety certificate issued vide letter no. F.6/DFS/MS/School/2020/SZ/484 dated 09/11/2020 for two blocks namely Old Block & New Block. At present MP hall is under renovation therefore FSC is recommended for two blocks namely Old Block & New Block except MP Hall.

*R.K. Yadav*  
18/10/2023

Signature of Inspecting Officer  
Name:- R.K. Yadav  
Designation:- Asstt. Divisional Officer

D.O (South West)

*[Signature]*  
19/10/23

Chof (SZ)  
*[Signature]*  
19/10/2023

Director  
*[Signature]*  
19/11/23

N See