



FIRE SAFETY CERTIFICATE

Certified that the **Dashmesh Public School at Vasundhara Enclave, Delhi-110096**, now comprised of **Basement + Ground + 03 upper floors only** (Earlier it Basement + Ground + 02 upper floors only for which Fire Safety Certificate was issued by this department vide letter No. F6/DFS/MS/School/NDZ/2020/322 dated 02/09/2020), have complied with fire prevention & fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010/ NBC Part - IV and verified by the officer concerned of Fire Service on 13.09.2023 in presence of Mrs. Manpreet Kaur (Principal) and that the building /premises is fit for occupancy class **"Educational"** (Group-B) with effect from 26/10/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 26/10/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Director of Education, (GNCT of Delhi), Civil Lines, Old Secretariat Delhi-110054.
2. The Principal, Dashmesh Public School at Vasundhara Enclave, Delhi-110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per BBL.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Dashmesh Public School at Vasundhara Enclave, Delhi-110096.		
2	Building is comprised of	Basement + Ground + 03 upper floors only.		
3	Type of occupancy	Educational Building		
4	Type of case	New Case / Alteration		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2020/322 dated 02.09.2020. Basement + Ground + 02 upper floors.		
6	Fire safety directives letter no.	F6/DFS/MS/BP/2020/352 dated 16.09.2020		
7	Date of inspection	13.10.2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Manpreet Kaur (Principal)		
10	Year of construction	2020		
11	Applicant's letter no.	Email dated - 22/09/2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A	Road width	6.0 mtrs.	15 mtrs. MR
	B	Gate width	4.5 mtrs	4.5 mtrs MR
	C	Width of internal road	N/A	6.0 mtrs MR
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
		a	Upper floor	03 nos. 03 nos. MR
		b	Basement	03 nos. 03 nos. MR
	B	Width of staircases		
		a	Upper floor	1.50 mtrs. 02 nos. of 1.7 mtrs & 01no. of 1.8 mtrs MR
		b	Basement	1.50 mtrs. 02 nos. of 1.7 mtrs & 01no. of 1.8 mtrs MR
	C	Protection of exits	Required	Provided MR
		a	Fire check door	Required Provided MR
		b	Pressurization	N/A N/A N/A
	D	No. of continuous staircases to terrace	02 nos.	02 nos. MR
	E	Width of corridor	1.50 mtrs.	2.0 mtrs. MR
	F	Door size	1.0 mtrs.	1.0 mtrs. MR
3	Compartmentation:			
	A	Fire check door	Required	Provided MR
	B	Sealing of electrical shafts	Required	Sealed MR
	C	Fire rating of shaft door	N/A	N/A N/A
	D	Water curtain	N/A	N/A N/A
	E	Fire dampers	N/A	N/A N/A
4	Smoke Management System:			
	A	Basement	Required	Provided MR
	B	Upper floor	N/A	N/A N/A

5. Fire Extinguisher:				
A	Total numbers	24 nos.	30 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	04 nos.	04 nos.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	Provided	MR
B	Location of main panel	N/A	Provided	MR
C	Location of repeater panel	N/A	Provided	MR
D	Alternate source of power	N/A	Provided	MR
E	Hooters	N/A	Provided	MR
8	MOEFA:	Required	Provided	MR
9	Public Address System:	Required	Provided	MR
10 Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	Required	Provided	MR
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	04 nos.	04 nos.	MR
C	Hose box	04 nos.	04 nos.	MR
12 Yard Hydrants:				
A	Total number of hydrants	04 nos.	04 nos.	MR
B	Hose box	04 nos.	04 nos.	MR
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	2280 LPM	2280 LPM	MR
B	Head of main pump	60 mtrs	60 mtrs	MR
C	Number of main pumps	01 no.	01 no.	MR
D	Jockey pump out put	180 LPM	180 LPM	MR
E	Jockey pump head	60 mtrs.	60 mtrs.	MR
F	Standby pump out put	2280 LPM	2280 LPM	MR
G	Standby pump head	60 mtrs.	60 mtrs.	MR
H	Auto starting /manual stopping	Required	Provided	MR
I	Pump house access	Required	Provided	MR
2 Terrace Level				
A	Discharge of pump	900 LPM	900 LPM	MR
B	Head of the pump	40 mtrs	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	2,00,000 ltrs.	Provided ✓	MR	
B	Draw-off connection	Required	Provided	MR	
C	Fire service inlet	Required	Provided	MR	
D	Access to tank	Required	Provided	MR	
E	Overhead tank capacity	25,000 ltrs.	25,000 ltrs. ✓	MR	
15	Exit Signage:		Required	Provided	MR
16	Provision of Lifts:				
A	Pressurization of lift shaft	Required	Provided	MR	
B	Pressurization of lift lobby	Required	Provided	MR	
C	Communication in lift car	Required	Provided	MR	
D	Firemen's grounding switch	Required	Provided	MR	
E	Lift signage	Required	Provided	MR	
17	Standby Power Supply:		Required	Provided	MR
18	Refuge Area:				
A	Total area	N/A	N/A	N/A	
B	Location	N/A	N/A	N/A	
19	Fire Control Room:				
A	Detector system panel	Required	Provided	MR	
B	Flow switch panel	Required	Provided	MR	
C	PA system panel	Required	Provided	MR	
D	Battery backup	Required	Provided	MR	
E	Building floor plans	Required	Provided	MR	
20	Special Fire Protection systems for protection of special Risks, if any:		Required	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.




Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

~~DO (E.D)~~

DFA please.

Dy. CFO (N.D.L)


21/10/2023

C.F.O.


21/10/23

23/10/2023

Director