



No. F6/DFS/MS/EH/2023/ 316

Dated: 26/10/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Food Sixteen (A Unit of Rinayra Hospitality) located at Upper Ground Floor, Adarsh Nagar, Delhi-110033 in the building comprised of basement, stilt, upper ground, & 03 upper floors owned/ occupied by M/s Food Sixteen (A Unit of Rinayra Hospitality) was issued fire safety certificate vide letter no. F6/DFS/MS/2020/WZ/EH/144 dated 15.10.2020. The premises was re-inspected by the officer concerned of Fire Service on 18.10.2023 in the presence of Sh. Pulkit Aggarwal and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "Group D Assembly" (Restaurant) on upper ground floor only with effect from 26/10/2023 ----- for a period of Valid up to 31.03.2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/10/2023.... at New Delhi by

(Atul Garg)
Director
Ph-011-23414000

Copy to:-

1. M/s Food Sixteen (A Unit of Rinayra Hospitality) located at Upper Ground Floor, Adarsh Nagar, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. This Fire Safety Certificate is valid only for restaurant on upper ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
4. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. All the staff members must know the correct method of operation of firefighting system.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Food Sixteen (A Unit of Rinayra Hospitality) at A-16, Upper Ground Floor, Adrash Nagar, Delhi-110033.
2. Type of Occupancy : Assembly/ (Restaurant)
3. Composition of building : Basement, stilt, upper ground & 03 upper floors but restaurant is running on upper ground floor only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2020/WZ/EH/144 dated 15.10.2020
6. Fire Safety directives letter No : Nil
7. Date of inspection : 19.10.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Pulkit Aggarwal
10. Year of Construction : 2015-16
11. Applicant's letter No. : Online MHA Portal I D No. 2023101017033 Dated: 16.10.2023

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL / NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	06m	MR
	• Gate width	NA	Directly Accessible	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	02m & 1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	NA	
f. Door Size	2.0m & 1.5m	Provided	MR	
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	06nos	08nos	MR

	<ul style="list-style-type: none"> Types ISI marking 	ABC & Co2	ABC- 08	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	Provided	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	UGF	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	UGF	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	Provided	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	UGF	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor (upper ground floor) 	NA	Provided	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	MR
	<ul style="list-style-type: none"> Hose Box 	01	01	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450lpm	MR
		40m	40m	MR
		NA	NA	NA
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NA	NA	NA
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000ltr	Provided	MR

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Note:-

- (a) The total covered area of the ground floor Restaurant is 217.73sqm (Approx.) including seating area, kitchen area, toilet area,
- (b) As per the NBC Part IV, the number of occupants comes out to be approx. 121 person's i.e. (217.73/1.8=121).

The fire protection systems provided in the building were tested/ checked and found in working condition at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules. It is recommended to renew Fire Safety vide this department letter of even no. F6/DFS/MS/2020/WZ/EH/144 dated.15.10.2020 Certificate under rule 37(3) of Delhi Fire Service Rules 2010.

Dy. Chief Fire Officer (WZ)

[Signature]
20/10

[Signature]
20/10/2023

Signature of the Inspecting Officer
Name :-C.L. Meena
Designation:- ADO/RN

24
20/10/2023

CFO
20/10/2023