



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2023/NDZ/763

Dated: 26/10/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Girls Sr. Sec. School**, located at **Jhilmil Colony, Delhi-110095**, building comprised of **Ground & One upper floor only**, owned / occupied by Govt. Girls Sr. Sec. School, was issued FSC vide letter No. F6/DFS/MS/School/2020/NDZ/440 Dt. 20/10/2020. The School building was re-inspected by the officer concerned of this department on **11/10/2023** in presence of **Smt. Karuna Bhardwaj (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with D.O.E circular No. F16/Estate/CC/FS/2011/3298 to 3398 Dated 01/03/2011 and that the building is fit for occupancy class **"Educational" (Group-B)** with effect from 26/10/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 26/10/2023 at New Delhi by

  
**(ATUL GARG)**  
**DIRECTOR**  
**DELHI FIRE SERVICE.**

Copy to:-

1. The Manager, Govt. Girls Sr. Sec. School, Jhilmil Colony, Delhi-110095.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/15

## INSPECTION REPORT

1. Name & address of the building: Govt. Girls Sr. Sec. School,  
Jhilmil Colony, Delhi-110095.
2. Building is comprised of : Ground & 1st Floor only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2020/NDZ/440 Dt. 20/10/2020
6. Fire Safety directives Letter No.: F.16/Estate/CC/FS/2011/3298-3398 Dt. 01/03/2011
7. Date of inspection : 11/10/2023
8. Name of the Inspecting Officer : A.K. Jaiswal, D.O. (E.D.)
9. Name and designation of Officer  
from the building side : SMT. Karuna Bhardwaj (Principal)
10. Year of Construction : 1967
11. Applicant's letter No. : E-Mail dated 23/09/2023

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular Requirements	Provided at Site	Remarks
1	Access to building			
	• Road width	06 m	15 m	M/R
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	➤ Upper Floor Block -A	01	01 ✓	M/R
	➤ Upper Floor Block -B	01	01 ✓	M/R
	➤ Upper Floor Block-C	01	02	M/R
	➤ Upper Floor Block-D	02	02 ✓	M/R
	➤ Upper Floor Block-E	01	01 ✓	M/R
	➤ Basement	N/A	N/A ✓	N/A
	b. Width of Staircases			
	• Upper Floor	1.50 m	1.50 m (each) ✓	M/R
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	1.50 m	1.50 m ✓	M/R
	f. Door size	1.00 m	1.00 m	M/R
3	Compartmentation			
	• Fire check Door	N/A	N/A	N/A
	• Sealing of electrical Shafts	N/A	N/A	N/A
	• Fire rating of Shaft Door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	20	35	M/R
	• Types	ABC & Co2	ABC & Co2	M/R
	• IS Marking	ISI Marked	ISI Marked	M/R

A

N/16

6	First-aid-Hose Reels			
	• Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false Ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	N/A	N/A	N/A
	• Number of Hydrants per Floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main Pumps	N/A	N/A	N/A
	➤ Jockey pump output	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump output	N/A	N/A	N/A
	➤ Standby pump head	N/A	N/A	N/A
	➤ Auto starting/Manual stopping	N/A	N/A	N/A
	➤ Pump house access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	N/A	N/A	N/A

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required in Director of Education Circular No. F.16/Estate/CC/FS/2011/3298-3398 Dt. 01/03/2011, The Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2020/NDZ/440 Dt. 20/10/2020 is recommended to be renewed.

*Ashok Kumar Jaiswal*  
11/11/2023

Signature of the Inspecting Officer  
Name: Ashok Kumar Jaiswal  
Designation: D.O. (East. Div.)

*Dy. C.O. (NDZ)*

*C.O.*  
*18/11/2023*

*Director*  
*19/11/23*

*OLFN*

*11/11/23*