



FIRE SAFETY CERTIFICATE

Certified that the Punjabi Cafe located at A-292, West Guru Angad Nagar, Laxmi Nagar, Delhi-110092, running at Ground floor only in a building comprised of Basement + Ground + 03 Upper floors, owned/occupied by Punjabi Cafe have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 13/10/2023 in the presence of Mr. Gajender Handa (Manager) and found that the building/premises is fit for occupancy class "Assembly" (Group D) (Restaurant at Ground floor only) and valid up to 31/03/2026 (Three Years) in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 25/10/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/c (u)

Copy to: -

1. The Manager, Punjabi Cafe located at A-292, West Guru Angad Nagar, Laxmi Nagar, Delhi-110092.
2. Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.r.t.- MHA portal ID - 2023092416362 dated 24.09.2023.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 Basement shall be used strictly as per Building By-Laws 1983.
- 9 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (l) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

N/4

INSPECTION REPORT

1	Name & address of the building	M/s Punjabi Cafe located at A-292, West Guru Angad Nagar, Laxmi Nagar, Delhi-110092.			
2	Building is comprised of	Basement + Ground + 03 upper floors. (Restaurant is running on Ground floor of the building)			
3	Type of occupancy	Assembly Building (Restaurant)			
4	Type of case	New Case			
5	Details of previous FSC	Nil			
6	Fire safety directives letter no.	NBC Part IV			
7	Date of inspection	13.10.2023			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side	Mr. Gajender Handa (Manager)			
10	Year of construction	2010			
11	Applicant's letter no.	Application no. 2023092416362 dated 24.09.2023			
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	9.0 mtrs.	60 mtrs	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
	a	Upper floor	N/A	N/A	N/A
	b	Basement	N/A	N/A	N/A
	B	Width of staircases			
	a	Upper floor	N/A	N/A	N/A
	b	Basement	N/A	N/A	N/A
	C	Protection of exits			
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	N/A	N/A	N/A
	E	Width of corridor	N/A	N/A	N/A
	F	Door size	1.50 mtrs x 2	1.60 mtrs & 1.50 mtrs	MR
3	Compartmentation:				
	A	Fire check door	Required	Provided	MR
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A

u

o

5. Fire Extinguisher:				
A	Total numbers	02 nos.	06 nos.	MR
B	Types	ABC& CO ₂	ABC& CO ₂	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:				
A	Total numbers	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8 MOEFA:		Required	Provided	MR
9 Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box	01 no.	01 no.	MR
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Terrace Level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Ground level				
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 M	40 M	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	20,000 ltrs	20,000 ltrs	MR
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage:	Required	provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	Required	provided	MR
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name: Yashwant Singh Meena
 Designation: ADO (L.N)

DO. (ED) *Ajay*

Ayefo (NDZ)

Rivp
19/11/23

e.f.p.
12/11/2023

2/11/23

18/10/2023