

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2023/SZ/318

Dated. 26/10/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of "The **ILLUSION LOUNGE AND BAR** located at **First Floor**, Shop No 11, 12 & 13, MGF Metropolitan Mall, Saket, New Delhi-110017 in the building comprised of 02 tiers Basement, Ground plus Seven upper Floors owned/occupied by A Unit of Forte Foods was issued FSC by this department vide letter no F6/DFS/EH/2020/SZ/71 dated 18/03/2020 for the name of MOBSTAR Ultra Lounge and Bar. The restaurant premise was re-inspected by the officers concerned of this department on 16/10/2023 in the presence of Mr. Sahil and found that the said restaurant premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy **Class- D "Assembly Building"** and **validity upto 31/03/2026** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/10/2023 at New Delhi by


(ATEL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, MCD, Public Health Department, Green Park, Delhi- 110016 (Ref. MHA Portal ID's 2023100216677 dated 05/10/2023, 2023101017058 dated 10/10/2023, and 2023092316322 dated 25/09/2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/24

INSPECTION REPORT

1	Name & Address of the Building	M/s The ILLUSION LOUNGE AND BAR (A Unit of Forte Foods) at Shop No 11, 12 & 13 First Floor, MGF Metropolitan Mall, Saket, New Delhi-110017		
2	Type of Occupancy	Restaurant at First Floor only		
3	Building Comprised of	02 tiers Basement, Ground plus Seven upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/EH/2020/SZ/71 dated 18/03/2020 for the name of MOBSTAR Ultra Lounge and Bar		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2005/2150 dated 14/10/2005		
7	Date of Inspection	16/10/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Sahil		
10	Year of construction	2007		
11	Applicant letter No.	MHA Portal ID 2023100216677 dated 05/10/2023, 2023101017058 dated 10/10/2023, 2023092316322 dated 25/09/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building. FSC- F6/DFS/MS/2019/SZ/464 dated 04/10/2023 for MGF Metropolitan Mall, Saket New Delhi			
	• Road width	09 mtr	Provided*	MR
	• Gate width	05 mtr	Provided*	MR
	• Width of internal road	06 mtr	Provided*	MR
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase	Provided & Maintained by MGF Metropolitan Mall,		
	• Upper floors	02 Nos	Provided*	MR
	• Basement floor	02 Nos	Provided*	MR
	b. Width of Staircase	Provided & Maintained by MGF Metropolitan Mall,		
	• Upper floors	1.50 mtr each	Provided*	MR
	• Basement floor	1.50 mtr each	Provided*	MR
	c. Protection of exits	Provided & Maintained by MGF Metropolitan Mall,		
	• Fire check door	Required	Provided*	MR
	• Pressurization	Required	Provided*	MR
	d. No. of continuous staircase to terrace	Required	Provided*	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.50m /1m	1.50 mtr & 2.0 mtr	MR (old case)
3	Compartmentation.	Provided & Maintained by MGF Metropolitan Mall,		
	• Fire check door.	Required	Provided*	MR
	• Sealing of electrical shafts.	Required	Provided*	MR
	• Fire rating of shaft door.	2 hrs	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.	Provided & Maintained by MGF Metropolitan Mall,		
	• Basement	Required	Provided*	MR
	• Upper floors	Required	Provided*	MR
5	Fire Extinguishers.			
	• Total numbers	8 Nos	08 Nos.	MR
	• Types		ABC-04, W.CO ₂ -04	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.	Provided & Maintained by MGF Metropolitan Mall,		
	• Total numbers on each floor.		02 in Restaurant	MR
	• Length of hose-reel hose.	Hose Reel	30m	MR

	• Nozzle Diameter		5mm	MR
7	Automatic Fire Detection and Alarming system. Provided & Maintained by MGF Metropolitan			
	• Type of detectors	Required	Smoke & Heat	MR
	• Location of Main Panel	Required	Provided*	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided*	MR
	• Hooter's location	Required	Provided*	MR
8.	MOEFA	Required	Provided*	MR
9.	Public Address System	Required	Provided*	MR
10.	Automatic Sprinkler System Provided & Maintained by MGF Metropolitan Mall,			
	• Basement	Required	Provided*	MR
	• Upper floors	Required	Provided*	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants. Provided & Maintained by MGF Metropolitan Mall,			
	• Size of Riser/Down-corer	Required	Provided*	MR
	• Number of Hydrant per floor	Required	Provided*	MR
	• Hose box.	Required	Provided*	MR
12.	Yard Hydrants. Provided & Maintained by MGF Metropolitan Mall,			
	• Total number of hydrants.	Required	Provided*	MR
	• 2. Hose box.	Required	Provided*	MR
13.	Pumping arrangements.			
	• Ground Level	Provided & Maintained by MGF Metropolitan Mall,		
	➤ Discharge of main pump.	4500 LPM	Provided*	MR
	➤ Head of main pump.	60 mtr	Provided*	MR
	➤ Number of main pumps.	Two	Provided*	MR
	➤ Jockey Pump output.	180 LPM	Provided*	MR
	➤ Jockey Pump head.	60 mtr	Provided*	MR
	➤ Standby Pump output.	4500 LPM	Provided*	MR
	➤ Standby Pump head.	60 mtr	Provided*	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided*	MR
	➤ Access to pump house	Required	Provided*	MR
	• Terrace Level	Provided & Maintained by MGF Metropolitan Mall,		
	➤ Discharge of pump.	Required	Provided*	MR
	➤ Head of pump.	Required	Provided*	MR
	➤ Power supply.	Required	Provided*	MR
	➤ Auto starting of pump.	Required	Provided*	MR
14.	Captive water storage for Fire Fighting. Provided & Maintained by MGF Metropolitan Mall,			
	• Underground tank capacity.	3,00,000 Ltrs	Provided*	MR
	➤ Draw-off connection.	Required	Provided*	MR
	➤ Fire Service Inlet.	Required	Provided*	MR
	➤ Access to tank.	Required	Provided*	MR
	• Overhead tank capacity.	50,000 Ltrs	Provided*	MR
15.	Exit Signage.	Required	Provided*	MR
16.	Provision of Lifts. Provided & Maintained by MGF Metropolitan Mall,			
	• Pressurization of lift shaft.	Required	Provided*	MR
	• Pressurization of lift lobby.	Required	Provided*	MR
	• Communication in lift car.	Required	Provided*	MR
	• Fireman's switch.	Required	Provided*	MR
	• Lift signage.	Required	Provided*	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

Sl. No.	Fire Control Room.	Provided & Maintained by MGF Metropolitan Mall,		
		Required	Provided*	MR
19.	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	Required	Provided*	MR
		Required	Provided*	MR
		Required	Provided*	MR
		Required	Provided*	MR
		Required	Provided*	MR
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	Provided*	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 537 dated 27/09/2023.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no 6/DFS/EH/2020/SZ/71 dated 18/03/2020 for the name of MOBSTAR Ultra Lounge and Bar, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended for the name The ILLUSION LOUNGE AND BAR.

Accordingly, DFA is put up for approval and signature please.

[Handwritten Signature]

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

[Handwritten Signature]

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

FO (HQ)
+

[Handwritten Signature]
19/10/2023

Director

[Large Handwritten Signature]
19/10/23
ADG/BLD

HT PL

As approved, F-1. letter is put up to your signature pl.

[Handwritten Signature]
Director

[Handwritten Signature]
26/10