



FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI



No. F6/DFS/MS/SZ/2023/college/26

Dated: 25/10/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Trinity Institute of Professional Studies, Located at Sector - 09, Dwarka, New Delhi - 110075 comprised of Basement + Ground + 8 UFs was issued Fire Safety Certificate vide letter No: F6/DFS/MS/2020/SZ/342, dated 03/09/2020. The premises was re inspected by the officer concerned of this department on 16/10/2023 in the presence of Dr. Ashutosh Agarwal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 under Delhi Fire Service Act 2007 and that the premises is fit for occupancy class "Educational" Group B with effect from 25/10/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/10/2023... at New Delhi by.


(Mul Garg)
Director
Delhi Fire Service


Copy to:

1. Directorate of Education Old Secretariat Delhi - 110054.
2. The, Director Trinity Institute of Professional Studies, Located at Sector - 09, Dwarka, New Delhi - 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Trinity Institute of Professional Studies,
Located at Sector - 09, Dwarka, New Delhi - 110075.
2. Type of Occupancy : Educational (Basement + Ground+ 8 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2020/SZ/342, dated 03/09/2020
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2017/208, dated 03/07/2017
6. Date of inspection : 16/10/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side: Dr. Ashutosh Agarwal
9. Year of Construction : 2007 & 2017
10. Applicant's letter No. : Nil dated 24/08/2023

Total Area = 2021 sqm.
Covered Area = 4954.39 sqm
Class rooms = 22
No. of students = 1789

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/42, N/43 & N/44	Provided at site	Remarks MR/NMR	
1.	Access of building	18 mtr	Provided	MR	
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 mtr	Provided	MR	
		06 mtr	5.7m to 6m	MR (Being old case)	
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases	02Nos.	Provided	MR	
		02 Nos. + Ramp	Provided	MR	
	b. Width of staircases	2X1.5 mtr	Provided	MR	
		1.5 m + ramp	Provided	MR	
	c. Protection of exits	Required	Provided	MR	
		Required	Provided	MR	
		02 Nos.	Provided	MR	
	d. No of continuous staircase to terrace	1.5 mtr	Provided	MR	
		Required	1 mtr Provided	MR (Being old case)	
	3.	Compartmentation			
		<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
			Required	Sealed	MR
NA			NA	NA	
NA			NA	NA	
NA			NA	NA	
4.	Smoke managements System				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c charge	Provided	MR	
		12 a/c charge	Natural ventilation	MR	

[Handwritten Signature]


5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	26 nos. ABC & CO ₂ ISI marked	Provided ABC & CO ₂ ISI marked	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	2 Nos. each floor 30 mtr 05 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA	Smoke provided in corridor at each floor and basement At Basement Provided on Upper Floors Battery Backup Appropriate places Near Staircases	NA NA NA NA MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NA NA	Provided in basement NA NA	MR NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm 02 Nos. Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	06 Nos. Required	Provided Provided	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto starting/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	1620 LPM 70 M 01 180 LPM 70 M 1620 LPM 70 M Required Required NA NA NA NA	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided NA NA NA NA	MR MR MR MR MR MR MR MR MR MR NA NA NA NA




Handwritten signature/initials


14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000 ltr	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required in fire tower	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	➤ Total area	Required	Old Case	MR (Being old case)
	➤ Location	7 th floor	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/2020/SZ/342, dated 03/09/2020 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Sign of Inspecting Officer
 Name: Udai vir Singh
 Designation: ADO/DWK




 Director 18/10/2023


 ADO/DWK